

NEMA HP 5

ELECTRICAL AND ELECTRONIC
CROSSLINKED, MODIFIED
POLYETHYLENE (XLPE) INSULATED
125°C HOOK-UP WIRE,
TYPES L (600 V), LL (1000 V),
AND LX (3000 V)

NEMA Standards Publication HP 5-2009

*Electrical and Electronic Crosslinked, Modified Polyethylene (XLPE) Insulated
125°C Hook-Up Wire, Types L (600 V), LL (1000 V), and LX (3000 V)*

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 1752

Rosslyn, Virginia 22209

www.nema.org

© Copyright 2009 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

		Page
	Foreword.....	iii
Section 1	GENERAL	
1.1	Scope.....	1
1.2	Referenced Standards and Specifications	1
1.3	Recommended Uses of Wire Types.....	2
	1.3.1 Type L.....	2
	1.3.2 Type LL.....	2
	1.3.3 Type LX	2
1.4	Part Identification Number (PIN).....	2
Section 2	CONDUCTORS	
2.1	Conductor Materials	4
2.2	Conductor Coatings.....	4
	2.2.1 Tin-Coated Conductors	4
	2.2.2 Silver-Coated Conductors	4
2.3	Stranding	4
2.4	Minimum Wire Diameter	4
2.5	Conductor Splices	4
Section 3	INSULATION	
3.1	General.....	6
3.2	XLPE Insulation	6
Section 4	WIRE IDENTIFICATION	
4.1	Circuit Identification	9
	4.1.1 Lay of Stripes.....	9
4.2	Identification by Printing	9
	4.2.1 Identification of Product.....	9
Section 5	PHYSICAL AND ELECTRICAL REQUIREMENTS	
5.1	General.....	10
5.2	Quality Conformance Inspection of Finished Product	10
	5.2.1 Definitions.....	10
	5.2.2 Sampling Inspection	10
5.3	Workmanship.....	10
5.4	Materials Certification	10
Section 6	TEST PROCEDURES	
6.1	Physical Tests.....	12
	6.1.1 Test Temperature	12
	6.1.2 Heat Resistance	12
	6.1.3 Insulation Tensile Strength and Elongation.....	12
	6.1.4 Dimensional Inspection	12
	6.1.5 Shrinkage.....	13
	6.1.6 Flammability	13
	6.1.7 Heat Aging Test.....	13
	6.1.8 Fungus Resistance.....	13
	6.1.9 Cold Bend	13

6.2	Electrical Tests	14
6.2.1	Conductor Resistance	14
6.2.2	Spark or Impulse Test	14
6.2.3	Dielectric Strength	14
6.2.4	Insulation Resistance	14
Section 7	NOTES	
7.1	Packaging Requirements	15
7.2	Labeling	15
7.3	Lengths	15
Section 8	ORDERING DATA	
8.1	Ordering Information.....	16
TABLES		
1-1	Conductor Material and Coating.....	3
1-2	AWG Nominal Conductor Size	3
1-3	Number of Strands	3
1-4	Color	3
2-1	Details of Conductors	5
3-1	Dimensions-Type Wires	7
4-1	Length of Lay of Stripes.....	9
5-1	Physical and Electrical Requirements for Type L, LL, and LX Wires	11
7-1	Minimum Lengths	15

FOREWORD

This Standards Publication was developed by the NEMA High Performance Wire and Cable Section. It was developed to ensure that these types of hook-up wire can be procured and that they will meet requirements associated with high reliability commercial electrical and electronic equipment in which it is used. Compliance with provisions of this Standards Publication is strictly voluntary and any certification of compliance is left to the discretion of the buyer and seller.

This Standards Publication was designed as a non-government standard for replacement of MIL-W-16878 XLPE insulated wire slash sheets (/14, /15, /16,).

This Standards Publication was developed by the High Performance Wire and Cable Section of NEMA. Section approval of the standard does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the Section was composed of the following members:

AFC Cable Systems—New Bedford, MA
AmerCable—El Dorado, AR
American Insulated Wire Corporation—Pawtucket, RI
Belden CDT, Inc.—St. Louis, MO
Berk-Tek a Nexans Company—Elm City, NC
Cable USA, Inc.—Naples, FL
Coleman Cable Inc.—Waukegan, IL
Draka Comteq USA Inc.—Franklin, MA
Fisk Alloy Conductors, Inc.—Hawthorne, NJ
General Cable—Highland Heights, KY
Harbour Industries, Inc.—Shelburne, VT
Judd Wire, Inc.—Turners Falls, MA
Kaneka High-Tech Materials, Inc.—Pasadena, TX
Leoni Wire, Inc.—Chicopee, MA
Leviton Manufacturing Co., Inc.—Gardena, CA
Phelps Dodge High Performance Conductors—Inman, SC
Quirk Wire Company, Inc.—West Brookfield, MA
Radix Wire Company—Euclid, OH
Rea Magnet Wire Company, Inc.—Fort Wayne, IN
Rockbestos-Surprenant Cable Corporation—East Granby, CT
Southwire Company—Carrollton, GA
Specialty Cable Corporation—Wallingford, CT
The Monroe Cable Company, Inc.—Middletown, NY
The Okonite Company—Ramsey, NJ
Tyco Electronics/Raychem Wire & Cable—Menlo Park, CA

< This page is intentionally left blank. >

Section 1 GENERAL

1.1 SCOPE

This Standards Publication covers specific requirements for crosslinked, modified polyethylene insulated solid and stranded wire, designed to the internal wiring of high reliability electrical and electronic equipment. This Standards Publication addresses 600 V (Type L), 1000 V (Type LL), and 3000 V (Type LX) wire and permits continuous conductor temperature ratings of -65°C to $+125^{\circ}\text{C}$ with either tin-coated, or silver-coated conductors. These types of hook-up wire are used when the following requirements are called for:

- Moderate temperature resistance
- Low temperature resistance
- Moderate dielectric constant
- Good flexibility and flex life when stranded conductors are used
- Solder iron resistance for easier solder terminations without potential damage
- Good fire resistance