

Revised pages to MG 1-2006 include MG 1-2006 Errata

Please replace the following pages of MG 1-2006:

MG 1-2006 Rev 1 Table of Contents (entirely revised)
MG 1-2006 Rev 1 Part 1 (entire Part 1))
MG 1-2006 Rev 1 Part 2 (entire Part 2)
MG 1-2006 Rev 1 Part 4 (pp 29-42 only)
MG 1-2006 Rev 1 Part 10 Ratings—AC Motors (pp 9-12) and
Ratings—DC Motors (pp 17-20)
MG 1-2006 Rev 1 Part 12 Tests and Performance—AC Motors (pp 15-40) and
Tests and Performance—DC Motors (pp 41-52 replace pp 35-44)
MG 1-2006 Rev 1 Part 15 (entire Part 15)
MG 1-2006 Rev 1 Part 20 (pp 5-6, 13-14)
MG 1-2006 Rev 1 Part 21 (pp 9-12; 25-26; 33-36)
MG 1-2006 Rev 1 Part 23 (pp 9-18)
MG 1-2006 Rev 1 Part 24 (entire Part 24)
MG 1-2006 Rev 1 Part 31 (pp 7-14)
MG 1-2006 Rev 1 Part 32 (entire Part 32)
MG 1-2006 Rev 1 Part 33 (pp 9-34)

NEMA Standards Publication MG 1-2006 Revision 1-2007

Motors and Generators

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 1752

Rosslyn, VA 22209

www.nema.org

© Copyright 2006 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

	Page No.
Foreword.....	xxxv
 Section I GENERAL STANDARDS APPLYING TO ALL MACHINES	
Part 1—REFERENCED STANDARDS AND DEFINITIONS	1-1
1.1 REFERENCED STANDARDS.....	1-1
DEFINITIONS	1-5
CLASSIFICATION ACCORDING TO SIZE	1-5
1.2 MACHINE	1-5
1.3 SMALL (FRACTIONAL) MACHINE	1-5
1.4 MEDIUM (INTEGRAL) MACHINE	1-5
1.4.1 Alternating-Current Medium Machine	1-5
1.4.2 Direct-Current Medium Machine.....	1-5
1.5 LARGE MACHINE	1-5
1.5.1 Alternating-Current Large Machine.....	1-5
1.5.2 Direct-Current Large Machine	1-6
CLASSIFICATION ACCORDING TO APPLICATION	1-6
1.6 GENERAL PURPOSE MOTOR.....	1-6
1.6.1 General-Purpose Alternating-Current Motor	1-6
1.6.2 General-Purpose Direct-Current Small Motor	1-6
1.7 GENERAL-PURPOSE GENERATOR	1-6
1.8 INDUSTRIAL SMALL MOTOR	1-6
1.9 INDUSTRIAL DIRECT-CURRENT MEDIUM MOTOR	1-6
1.10 INDUSTRIAL DIRECT-CURRENT GENERATOR	1-6
1.11 DEFINITE-PURPOSE MOTOR	1-7
1.12 GENERAL INDUSTRIAL MOTORS	1-7
1.13 METAL ROLLING MILL MOTORS	1-7
1.14 REVERSING HOT MILL MOTORS	1-7
1.15 SPECIAL-PURPOSE MOTOR	1-7
1.16 NEMA PREMIUM® EFFICIENCY MOTOR.....	1-7
1.16.1 60 Hz.....	1-7
1.16.2 50 Hz.....	1-7
CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	1-8
1.17 GENERAL.....	1-8
1.17.1 Electric Motor	1-8
1.17.2 Electric Generator	1-8
1.17.3 Electric Machines.....	1-8
1.18 ALTERNATING-CURRENT MOTORS.....	1-9
1.18.1 Induction Motor	1-9
1.18.2 Synchronous Motor	1-9
1.18.3 Series-Wound Motor	1-10
1.19 POLYPHASE MOTORS	1-10
1.19.1 Design Letters of Polyphase Squirrel-Cage Medium Motors	1-10
1.20 SINGLE-PHASE MOTORS	1-10
1.20.1 Design Letters of Single-Phase Small Motors	1-10
1.20.2 Design Letters of Single-Phase Medium Motors	1-11
1.20.3 Single-Phase Squirrel-Cage Motors	1-11
1.20.4 Single-Phase Wound-Rotor Motors.....	1-12
1.21 UNIVERSAL MOTORS.....	1-12
1.21.1 Series-Wound Motor	1-12
1.21.2 Compensated Series-Wound Motor	1-12
1.22 ALTERNATING-CURRENT GENERATORS.....	1-12
1.22.1 Induction Generator	1-12
1.22.2 Synchronous Generator.....	1-13

1.23	DIRECT-CURRENT MOTORS	1-13
1.23.1	Shunt-Wound Motor	1-13
1.23.2	Series-Wound Motor	1-13
1.23.3	Compound-Wound Motor	1-13
1.23.4	Permanent Magnet Motor	1-13
1.24	DIRECT-CURRENT GENERATORS	1-13
1.24.1	Shunt-Wound Generator	1-13
1.24.2	Compound-Wound Generator	1-13
CLASSIFICATION ACCORDING TO ENVIRONMENTAL PROTECTION AND METHODS		
	OF COOLING	1-14
1.25	OPEN MACHINE (IP00, IC01)	1-14
1.25.1	Dripproof Machine (IP12, IC01)	1-14
1.25.2	Splash-Proof Machine (IP13, IC01)	1-14
1.25.3	Semi-Guarded Machine (IC01)	1-14
1.25.4	Guarded Machine (IC01)	1-14
1.25.5	Dripproof Guarded Machine (IC01)	1-17
1.25.6	Open Independently Ventilated Machine (IC06)	1-17
1.25.7	Open Pipe-Ventilated Machine	1-17
1.25.8	Weather-Protected Machine	1-17
1.26	TOTALLY ENCLOSED MACHINE	1-17
1.26.1	Totally Enclosed Nonventilated Machine (IC410)	1-17
1.26.2	Totally Enclosed Fan-Cooled Machine	1-17
1.26.3	Totally Enclosed Fan-Cooled Guarded Machine (IC411)	1-18
1.26.4	Totally Enclosed Pipe-Ventilated Machine (IP44)	1-18
1.26.5	Totally Enclosed Water-Cooled Machine (IP54)	1-18
1.26.6	Water-Proof Machine (IP55)	1-18
1.26.7	Totally Enclosed Air-to-Water-Cooled Machine (IP54)	1-18
1.26.8	Totally Enclosed Air-to-Air-Cooled Machine (IP54)	1-18
1.26.9	Totally Enclosed Air-Over Machine (IP54, IC417)	1-18
1.26.10	Explosion-Proof Machine	1-19
1.26.11	Dust-Ignition-Proof Machine	1-19
1.27	MACHINE WITH ENCAPSULATED OR SEALED WINDINGS	1-19
1.27.1	Machine with Moisture Resistant Windings	1-19
1.27.2	Machine with Sealed Windings	1-19
CLASSIFICATION ACCORDING TO VARIABILITY OF SPEED		
1.30	CONSTANT-SPEED MOTOR	1-19
1.31	VARYING-SPEED MOTOR	1-19
1.32	ADJUSTABLE-SPEED MOTOR	1-20
1.33	BASE SPEED OF AN ADJUSTABLE-SPEED MOTOR	1-20
1.34	ADJUSTABLE VARYING-SPEED MOTOR	1-20
1.35	MULTISPEED MOTOR	1-20
RATING, PERFORMANCE, AND TEST		
1.40	RATING OF A MACHINE	1-20
1.40.1	Continuous Rating	1-20
1.40.2	Short-Time Rating	1-20
1.41	EFFICIENCY	1-20
1.41.1	General	1-20
1.41.2	Energy Efficient Polyphase Squirrel-Cage Induction Motor	1-20
1.42	SERVICE FACTOR—AC MOTORS	1-21
1.43	SPEED REGULATION OF DC MOTORS	1-21
1.43.1	Percent Compounding of Direct-Current Machines	1-21
1.44	VOLTAGE REGULATION OF DIRECT-CURRENT GENERATORS	1-21
1.45	SECONDARY VOLTAGE OF WOUND-MOTOR ROTORS	1-21
1.46	FULL-LOAD TORQUE	1-21
1.47	LOCKED-ROTOR TORQUE (STATIC TORQUE)	1-21
1.48	PULL-UP TORQUE	1-21

1.49	PUSHOVER TORQUE	1-21
1.50	BREAKDOWN TORQUE	1-21
1.51	PULL-OUT TORQUE	1-22
1.52	PULL-IN TORQUE	1-22
1.53	LOCKED-ROTOR CURRENT	1-22
1.54	NO-LOAD CURRENT	1-22
1.55	TEMPERATURE TESTS	1-22
1.56	AMBIENT TEMPERATURE	1-22
1.57	HIGH-POTENTIAL TESTS	1-22
1.58	STARTING CAPACITANCE FOR A CAPACITOR MOTOR	1-22
1.59	RADIAL MAGNETIC PULL AND AXIAL CENTERING FORCE	1-22
	1.59.1 Radial Magnetic Pull	1-22
	1.59.2 Axial Centering Force	1-23
1.60	INDUCTION MOTOR TIME CONSTANTS	1-23
	1.60.1 General	1-23
	1.60.2 Open-Circuit AC Time Constant	1-23
	1.60.3 Short-Circuit AC Time Constant	1-23
	1.60.4 Short-Circuit DC Time Constant	1-23
	1.60.5 X/R Ratio	1-23
	1.60.6 Definitions (See Figure 1-4)	1-23
	COMPLETE MACHINES AND PARTS	1-24
1.61	SYNCHRONOUS GENERATOR—COMPLETE	1-24
	1.61.1 Belted Type	1-24
	1.61.2 Engine Type	1-24
	1.61.3 Coupled Type	1-24
1.62	DIRECT-CURRENT GENERATOR—COMPLETE	1-24
	1.62.1 Belted Type	1-24
	1.62.2 Engine Type	1-24
	1.62.3 Coupled Type	1-24
1.63	FACE AND FLANGE MOUNTING	1-24
	1.63.1 Type C Face	1-24
	1.63.2 Type D Flange	1-25
	1.63.3 Type P Flange	1-25
	CLASSIFICATION OF INSULATION SYSTEMS	1-25
1.65	INSULATION SYSTEM DEFINED	1-25
	1.65.1 Coil Insulation with its Accessories	1-25
	1.65.2 Connection and Winding Support Insulation	1-25
	1.65.3 Associated Structural Parts	1-25
1.66	CLASSIFICATION OF INSULATION SYSTEMS	1-25
	MISCELLANEOUS	1-26
1.70	NAMEPLATE MARKING	1-26
	1.70.1 Nameplate	1-26
	1.70.2 Additional Nameplate Markings	1-26
1.71	CODE LETTER	1-27
1.72	THERMAL PROTECTOR	1-27
1.73	THERMALLY PROTECTED	1-27
1.74	OVER TEMPERATURE PROTECTION	1-27
1.75	PART-WINDING START MOTOR	1-27
1.76	STAR (WYE) START, DELTA RUN MOTOR	1-27
1.77	CONSTANT FLUX	1-27
1.78	DEVIATION FACTOR	1-27
1.79	MARKING ABBREVIATIONS FOR MACHINES	1-28

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 2—TERMINAL MARKINGS

GENERAL	2-1
----------------------	-----

2.1	LOCATION OF TERMINAL MARKINGS	2-1
2.2	TERMINAL MARKINGS.....	2-1
2.3	DIRECTION OF ROTATION	2-2
2.3.1	Alternating-Current Machines	2-2
2.3.2	Direct-Current Machines	2-2
2.3.3	Motor-Generator Sets	2-2
DC MOTORS AND GENERATORS		2-2
2.10	TERMINAL MARKINGS.....	2-2
2.10.1	General	2-2
2.10.2	Armature Leads	2-2
2.10.3	Armature Leads—Direction of Rotation	2-2
2.11	TERMINAL MARKINGS FOR DUAL VOLTAGE SHUNT FIELDS	2-2
2.12	DIRECTION OF ROTATION	2-3
2.12.1	Direct-Current Motors	2-3
2.12.2	Direct-Current Generators	2-3
2.12.3	Reverse Function.....	2-3
2.13	CONNECTION DIAGRAMS WITH TERMINAL MARKINGS FOR DIRECT-CURRENT MOTORS.....	2-3
2.14	CONNECTION DIAGRAMS WITH TERMINAL MARKINGS FOR DIRECT-CURRENT GENERATORS	2-7
AC MOTORS AND GENERATORS		2-9
2.20	NUMERALS ON TERMINALS OF ALTERNATING-CURRENT POLYPHASE MACHINES	2-9
2.20.1	Synchronous Machines	2-9
2.20.2	Induction Machines	2-9
2.21	DEFINITION OF PHASE SEQUENCE	2-9
2.22	PHASE SEQUENCE.....	2-9
2.23	DIRECTION OF ROTATION OF PHASORS.....	2-9
2.24	DIRECTION OF ROTATION	2-10
AC GENERATORS AND SYNCHRONOUS MOTORS		2-10
2.25	REVERSAL OF ROTATION, POLARITY AND PHASE SEQUENCE	2-10
2.30	CONNECTION AND TERMINAL MARKINGS—ALTERNATING- CURRENT GENERATORS AND SYNCHRONOUS MOTORS— THREE-PHASE AND SINGLE-PHASE	2-10
SINGLE PHASE MOTORS		2-11
2.40	GENERAL.....	2-11
2.40.1	Dual Voltage	2-11
2.40.2	Single Voltage.....	2-11
2.41	TERMINAL MARKINGS IDENTIFIED BY COLOR.....	2-12
2.42	AUXILIARY DEVICES WITHIN MOTOR.....	2-12
2.43	AUXILIARY DEVICES EXTERNAL TO MOTOR.....	2-12
2.44	MARKING OF RIGIDLY MOUNTED TERMINALS.....	2-12
2.45	INTERNAL AUXILIARY DEVICES PERMANENTLY CONNECTED TO RIGIDLY MOUNTED TERMINALS.....	2-13
2.46	GENERAL PRINCIPLES FOR TERMINAL MARKINGS FOR SINGLE-PHASE MOTORS	2-13
2.46.1	First Principle	2-13
2.46.2	Second Principle	2-13
2.46.3	Third Principle	2-13
2.47	SCHEMATIC DIAGRAMS FOR SPLIT-PHASE MOTORS— SINGLE VOLTAGE—REVERSIBLE	2-14
2.47.1	Without Thermal Protector	2-14
2.47.2	With Thermal Protector.....	2-14
2.48	SCHEMATIC DIAGRAMS FOR CAPACITOR-START MOTORS— REVERSIBLE	2-15
2.48.1	Single-Voltage Capacitor-start Motors—Reversible	2-15

2.48.2	Dual-Voltage Capacitor-start Motors—Reversible.....	2-16
2.49	SCHEMATIC DIAGRAMS FOR TWO-VALUE CAPACITOR MOTORS—SINGLE VOLTAGE—REVERSIBLE	2-20
2.49.1	Without Thermal Protector	2-20
2.49.2	With Thermal Protector	2-21
2.50	SCHEMATIC DIAGRAMS FOR PERMANENT-SPLIT CAPACITOR MOTORS—SINGLE VOLTAGE—REVERSIBLE	2-22
2.51	SCHEMATIC DIAGRAMS FOR UNIVERSAL MOTORS— SINGLE VOLTAGE	2-23
2.52	SCHEMATIC DIAGRAMS FOR REPULSION, REPULSION-START INDUCTION, AND REPULSION-INDUCTION MOTORS	2-24
2.53	SHADED-POLE MOTORS—TWO SPEED	2-25
2.60	GENERAL PRINCIPLES FOR TERMINAL MARKINGS FOR POLYPHASE INDUCTION MOTORS	2-25
2.60.1	Method of Marking	2-25
2.60.2	Three-Phase, Two Speed Motors	2-27
2.60.3	Two-Phase Motors	2-27
2.61	TERMINAL MARKINGS FOR THREE-PHASE SINGLE-SPEED INDUCTION MOTORS	2-27
2.61.1	First	2-27
2.61.2	Second	2-27
2.61.3	Third	2-27
2.61.4	Fourth	2-27
2.61.5	Fifth	2-27
2.61.6	Sixth	2-28
2.62	TERMINAL MARKINGS FOR Y- AND DELTA-CONNECTED DUAL VOLTAGE MOTORS	2-28
2.63	TERMINAL MARKINGS FOR THREE-PHASE TWO-SPEED SINGLE-WINDING INDUCTION MOTORS	2-28
2.64	TERMINAL MARKINGS FOR Y- AND DELTA-CONNECTED THREE-PHASE TWO-SPEED SINGLE-WINDING MOTORS	2-28
2.65	TERMINAL MARKINGS FOR THREE-PHASE INDUCTION MOTORS HAVING TWO OR MORE SYNCHRONOUS SPEEDS OBTAINED FROM TWO OR MORE INDEPENDENT WINDINGS	2-34
2.65.1	Each Independent Winding Giving One Speed	2-34
2.65.2	Each Independent Winding Reconnectible to Give Two Synchronous Speeds	2-34
2.65.3	Two or More Independent Windings at Least One of Which Gives One Synchronous Speed and the Other Winding Gives Two Synchronous Speeds	2-35
2.66	TERMINAL MARKINGS OF THE ROTORS OF WOUND-ROTOR INDUCTION MOTORS	2-36

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 3—HIGH-POTENTIAL TESTS

3.1	HIGH-POTENTIAL TESTS	3-1
3.1.1	Safety	3-1
3.1.2	Definition	3-1
3.1.3	Procedure	3-1
3.1.4	Test Voltage	3-1
3.1.5	Condition of Machine to be Tested	3-1
3.1.6	Duration of Application of Test Voltage	3-1
3.1.7	Points of Application of Test Voltage	3-2
3.1.8	Accessories and Components	3-2
3.1.9	Evaluation of Dielectric Failure	3-2
3.1.10	Initial Test at Destination	3-2

3.1.11 Tests of an Assembled Group of Machines and Apparatus	3-2
3.1.12 Additional Tests Made After Installation	3-3

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 4—DIMENSIONS, TOLERANCES, AND MOUNTING

4.1	LETTERING OF DIMENSION SHEETS.....	4-1
4.2	SYSTEM FOR DESIGNATING FRAMES.....	4-10
4.2.1	Frame Numbers	4-10
4.2.2	Frame Letters.....	4-11
4.3	MOTOR MOUNTING AND TERMINAL HOUSING LOCATION.....	4-12
4.4	DIMENSIONS—AC MACHINES	4-14
4.4.1	Dimensions for Alternating-Current Foot-Mounted Machines with Single Straight-Shaft Extension	4-14
4.4.2	Shaft Extensions and Key Dimensions for Alternating- Current Foot-Mounted Machines with Single Tapered or Double Straight/Tapered Shaft Extension	4-16
4.4.3	Shaft Extension Diameters and Key Dimensions for Alternating-Current Motors Built in Frames Larger than the 449T Frames	4-17
4.4.4	Dimensions for Type C Face-Mounting Foot or Footless Alternating-Current Motors.....	4-17
4.4.5	Dimensions for Type FC Face Mounting for Accessories on End of Alternating-Current Motors	4-18
4.4.6	Dimensions for Type D Flange-Mounting Foot or Footless Alternating-Current Motors.....	4-19
4.5	DIMENSIONS—DC MACHINES	4-20
4.5.1	Dimensions for Direct-Current Small Motors with Single Straight Shaft Extension	4-20
4.5.2	Dimensions for Foot-Mounted Industrial Direct-Current Machines	4-21
4.5.3	Dimensions for Foot-Mounted Industrial Direct-Current Motors	4-25
4.5.4	Dimensions for Type C Face-Mounting Direct-Current Small Motors	4-26
4.5.5	Dimensions for Type C Face-Mounting Industrial Direct-Current Motors.....	4-26
4.5.6	Dimensions for Type C Face-Mounting Industrial Direct-Current Motors.....	4-27
4.5.7	Dimensions for Type D Flange-Mounting Industrial Direct-Current Motors	4-27
4.5.8	Base Dimensions for Type P and PH Vertical Solid-Shaft Industrial Direct-Current Motors.....	4-28
4.5.9	Dimensions for Type FC Face Mounting for Accessories on End Opposite Drive End of Industrial Direct-Current Motors	4-28
4.6	SHAFT EXTENSION DIAMETERS FOR UNIVERSAL MOTORS	4-28
4.7	TOLERANCE LIMITS IN DIMENSIONS.....	4-29
4.8	KNOCKOUT AND CLEARANCE HOLE DIAMETER FOR MACHINE TERMINAL BOXES	4-29
4.9	TOLERANCES ON SHAFT EXTENSION DIAMETERS AND KEYSEATS	4-29
4.9.1	Shaft Extension Diameter	4-29
4.9.2	Keyseat Width.....	4-29
4.9.3	Bottom of Keyseat to Shaft Surface.....	4-29
4.9.4	Parallelism of Keyseats to Shaft Centerline	4-30
4.9.5	Lateral Displacement of Keyseats	4-30
4.9.6	Diameters and Keyseat Dimensions	4-30
4.9.7	Shaft Runout	4-30
4.9.8	Shaft Extension Key(s)	4-31
4.10	RING GROOVE SHAFT KEYSEATS FOR VERTICAL SHAFT MOTORS	4-32
4.11	METHOD OF MEASUREMENT OF SHAFT RUNOUT AND OF ELECTRICITY AND FACE RUNOUT OF MOUNTING SURFACES	4-32

4.11.1	Shaft Runout	4-32
4.11.2	Eccentricity and Face Runout of Mounting Surfaces.....	4-32
4.12	TOLERANCES FOR TYPE C FACE MOUNTING AND TYPE D FLANGE MOUNTING MOTORS	4-33
4.13	TOLERANCES FOR TYPE P FLANGE-MOUNTING MOTORS.....	4-33
4.14	MOUNTING BOLTS OR STUDS.....	4-33
4.15	METHOD TO CHECK COPLANARITY OF FEET OF FULLY ASSEMBLED MOTORS	4-34
4.16	METHOD OF MEASUREMENT OF SHAFT EXTENSION PARALLELISM TO FOOT PLANE	4-34
4.17	MEASUREMENT OF BEARING TEMPERATURE	4-34
4.18	TERMINAL CONNECTIONS FOR SMALL MOTORS.....	4-35
4.18.1	Terminal Leads	4-35
4.18.2	Blade Terminals.....	4-35
4.19	MOTOR TERMINAL HOUSINGS	4-35
4.19.1	Small and Medium Motors	4-35
4.19.2	Dimensions	4-35
4.20	GROUNDING MEANS FOR FIELD WIRING	4-41

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 5—ROTATING ELECTRICAL MACHINES—CLASSIFICATION OF DEGREES OF PROTECTION PROVIDED BY ENCLOSURES FOR ROTATING MACHINES

5.1	SCOPE	5-1
5.2	DESIGNATION	5-1
5.2.1	Single Characteristic Numeral	5-1
5.2.2	Supplementary Letters.....	5-1
5.2.3	Example of Designation.....	5-2
5.2.4	Most Frequently Used.....	5-2
5.3	DEGREES OF PROTECTION—FIRST CHARACTERISTIC NUMERAL	5-2
5.3.1	Indication of Degree of Protection	5-2
5.3.2	Compliance to Indicated Degree of Protection	5-2
5.3.3	External Fans.....	5-2
5.3.4	Drain Holes	5-3
	Table 5-1	5-3
5.4	DEGREES OF PROTECTION—SECOND CHARACTERISTIC NUMERAL	5-4
5.4.1	Indication of Degree of Protection	5-4
5.4.2	Compliance to Indicated Degree of Protection	5-4
	Table 5-2	5-4
5.5	MARKING	5-5
5.6	GENERAL REQUIREMENTS FOR TESTS	5-5
5.6.1	Adequate Clearance	5-5
5.7	TESTS FOR FIRST CHARACTERISTIC NUMERAL	5-5
	Table 5-3	5-6
5.8	TESTS FOR SECOND CHARACTERISTIC NUMERAL.....	5-7
5.8.1	Test Conditions	5-7
	Table 5-4.....	5-8
5.8.2	Acceptance Conditions	5-10
5.8.3	Allowable Water Leakage	5-10
5.9	REQUIREMENTS AND TESTS FOR OPEN WEATHER-PROTECTED MACHINES	5-10
	Figure 5-1	5-11
	Figure 5-2	5-12
	Figure 5-3	5-13
	Figure 5-4	5-14
	Figure 5-5	5-15
	Figure 5-6	5-16

Section I GENERAL STANDARDS APPLICABLE TO ALL MACHINES

Part 6—ROTATING ELECTRICAL MOTORS—METHODS OF COOLING (IC CODE)

6.1	SCOPE	6-1
6.2	DEFINITIONS	6-1
6.2.1	Cooling	6-1
6.2.2	Coolant	6-1
6.2.3	Primary Coolant	6-1
6.2.4	Secondary Coolant	6-1
6.2.5	Final Coolant	6-1
6.2.6	Surrounding Medium	6-1
6.2.7	Remote Medium	6-2
6.2.8	Direct Cooled Winding (Inner-cooled Winding)	6-2
6.2.9	Indirect Cooled Winding	6-2
6.2.10	Heat Exchange	6-2
6.2.11	Pipe, Duct	6-2
6.2.12	Open Circuit	6-2
6.2.13	Closed Circuit	6-2
6.2.14	Piped or Ducted Circuit	6-2
6.2.15	Stand-by or Emergency Cooling System	6-2
6.2.16	Integral Component	6-2
6.2.17	Machine-Mounted Component	6-3
6.2.18	Separate Component	6-3
6.2.19	Dependent Circulation Component	6-3
6.2.20	Independent Circulation Component	6-3
6.3	DESIGNATION SYSTEM	6-3
6.3.1	Arrangement of the IC Code	6-3
6.3.2	Application of Designations	6-4
6.3.3	Designation of Same Circuit Arrangements for Different Parts of a Machine	6-4
6.3.4	Designation of Different Circuit Arrangements for Different Parts of a Machine	6-4
6.3.5	Designation of Direct Cooled Winding	6-5
6.3.6	Designation of Stand-by or Emergency Cooling Conditions	6-5
6.3.7	Combined Designations	6-5
6.3.8	Replacement of Characteristic Numerals	6-5
6.4	CHARACTERISTIC NUMERAL FOR CIRCUIT ARRANGEMENT	6-5
6.5	CHARACTERISTIC LETTERS FOR COOLANT	6-6
6.6	CHARACTERISTIC NUMERAL FOR METHOD OF MOVEMENT	6-7
6.7	COMMONLY USED DESIGNATIONS	6-8
6.7.1	General Information on the Tables	6-8

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 7—MECHANICAL VIBRATION-MEASUREMENT, EVALUATION AND LIMITS

(Entire Section Replaced)

7.1	SCOPE	7-1
7.2	OBJECT	7-1
7.3	REFERENCES	7-1
7.4	MEASUREMENT QUANTITY	7-1
7.4.1	Bearing Housing Vibration	7-1
7.4.2	Relative Shaft Vibration	7-1
7.5	MEASUREMENT EQUIPMENT	7-2
7.6	MACHINE MOUNTING	7-2
7.6.1	General	7-2
7.6.2	Resilient Mounting	7-2
7.6.3	Rigid Mounting	7-2

	7.6.4 Active Environment Determination	7-3
7.7	CONDITIONS OF MEASUREMENT	7-3
	7.7.1 Shaft Key	7-3
	7.7.2 Measurement Points for Vibration	7-3
	7.7.3 Operating Conditions	7-4
	7.7.4 Vibration Transducer Mounting.....	7-4
7.8	LIMITS OF BEARING HOUSING VIBRATION.....	7-7
	7.8.1 General	7-7
	7.8.2 Vibration Limits for Standard Machines.....	7-9
	7.8.3 Vibration Limits for Special Machines.....	7-9
	7.8.4 Vibration Banding for Special Machines.....	7-9
	7.8.5 Twice Line Frequency Vibration of Two Pole Induction Machines.....	7-10
	7.8.6 Axial Vibration.....	7-11
7.9	LIMITS OF RELATIVE SHAFT VIBRATION.....	7-11
	7.9.1 General	7-11
	7.9.2 Standard Machines.....	7-12
	7.9.3 Special Machines.....	7-12

Section I GENERAL STANDARDS APPLYING TO ALL MACHINES

Part 9—ROTATING ELECTRICAL MOTORS—SOUND POWER LIMITS AND MEASUREMENT PROCEDURES

9.1	SCOPE	9-1
9.2	GENERAL.....	9-1
9.3	REFERENCES	9-1
9.4	METHODS OF MEASUREMENT	9-1
9.5	TEST CONDITIONS	9-2
	9.5.1 Machine Mounting	9-2
	9.5.2 Test Operating Conditions.....	9-2
9.6	SOUND POWER LEVEL	9-2
9.7	DETERMINATION OF SOUND PRESSURE LEVEL.....	9-3
	Table 9-1.....	9-4
	Table 9-2.....	9-5
	Table 9-3.....	9-5
	Table 9-4.....	9-6

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 10—AC SMALL AND MEDIUM MOTORS

10.0	SCOPE	10-1
10.30	VOLTAGES.....	10-1
10.31	FREQUENCIES	10-1
	10.31.1 Alternating-Current Motors	10-1
	10.31.2 Universal Motors.....	10-1
10.32	HORSEPOWER AND SPEED RATINGS.....	10-2
	10.32.1 Small Induction Motors, Except Permanent-Split Capacitor Motors Rated 1/3 Horsepower and Smaller and Shaded- Pole Motors	10-2
	10.32.2 Small induction Motors, permanent-Split Capacitor Motors Rated 1/3 Horsepower and Smaller and Shaded-Pole Motors.....	10-2
	10.32.3 Single-Phase Medium Motors.....	10-3
	10.32.4 Polyphase Medium Induction Motors	10-3
	10.32.5 Universal Motors.....	10-4
10.33	HORSEPOWER RATINGS OF MULTISPEED MOTORS	10-4
	10.33.1 Constant Horsepower	10-4
	10.33.2 Constant Torque	10-5
	10.33.3 Variable Torque	10-5
10.34	BASIS FOR HORSEPOWER RATING.....	10-5

10.34.1	Basis of Rating.....	10-5
10.34.2	Temperature	10-5
10.34.3	Minimum Breakdown Torque.....	10-5
10.35	SECONDARY DATA FOR WOUND-ROTOR-MOTORS	10-8
10.36	TIME RATINGS FOR SINGLE-PHASE AND POLYPHASE INDUCTION MOTORS	10-8
10.37	CODE LETTERS (FOR LOCKED-ROTOR KVA).....	10-8
10.37.1	Nameplate Marking.....	10-8
10.37.2	Letter Designation.....	10-8
10.37.3	Multispeed Motors	10-8
10.37.4	Single-Speed Motors	10-9
10.37.5	Broad- or Dual-Voltage Motors	10-9
10.37.6	Dual-Frequency Motors	10-9
10.37.7	Part-Winding-Start Motors	10-9
10.38	NAMEPLATE TEMPERATURE RATINGS FOR ALTERNATING- CURRENT SMALL AND UNIVERSAL MOTORS	10-9
10.39	NAMEPLATE MARKING FOR ALTERNATING-CURRENT SMALL AND UNIVERSAL MOTORS	10-9
10.39.1	Alternating-Current Single-Phase and Polyphase Squirrel- Cage Motors, Except Those Included in 10.39.2, 10.39.3, and 10.39.4	10-9
10.39.2	Motors Rated Less than 1/20 Horsepower	10-10
10.39.3	Universal Motors.....	10-10
10.39.4	Motors Intended for Assembly in a Device Having its Own Markings	10-10
10.39.5	Motors for Dual Voltage	10-10
10.40	NAMEPLATE MARKING FOR MEDIUM SINGLE-PHASE AND POLYPHASE INDUCTION MOTORS	10-11
10.40.1	Medium Single-Phase and Polyphase Squirrel-Cage Motors	10-11
10.40.2	Polyphase Wound-Rotor Motors.....	10-12

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 10—DC SMALL AND MEDIUM MOTORS

10.0	SCOPE	10-13
10.60	BASIS OF RATING.....	10-13
10.60.1	Small Motors	10-13
10.60.2	Medium Motors	10-13
10.61	POWER SUPPLY IDENTIFICATION FOR DIRECT-CURRENT MEDIUM MOTORS.....	10-13
10.60.1	Supplies Designated by a Single Letter.....	10-13
10.60.2	Other Supply Types	10-13
10.62	HORSEPOWER, SPEED, AND VOLTAGE RATINGS	10-14
10.62.1	Direct-Current Small Motors	10-14
10.62.2	Industrial Direct-Current Motors.....	10-15
10.63	NAMEPLATE TIME RATING	10-15
10.64	TIME RATING FOR INTERMITTENT, PERIODIC, AND VARYING DUTY	10-15
10.65	NAMEPLATE MAXIMUM AMBIENT TEMPERATURE AND INSULATION SYSTEM CLASS.....	10-15
10.66	NAMEPLATE MARKING	10-17
10.66.1	Small Motors Rated 1/20 Horsepower and Less.....	10-17
10.66.2	Small Motors Except Those Rated 1/20 Horsepower and Less.....	10-18
10.66.3	Medium Motors	10-18

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 12—TESTS AND PERFORMANCE—AC AND DC MOTORS

12.0	SCOPE	12-1
12.2	HIGH-POTENTIAL TEST—SAFETY PRECAUTIONS AND TEST PROCEDURE	12-1
12.3	HIGH-POTENTIAL TEST VOLTAGES FOR UNIVERSAL, INDUCTION, AND DIRECT-CURRENT MOTORS	12-1
12.4	PRODUCTION HIGH-POTENTIAL TESTING OF SMALL MOTORS	12-2
	12.4.1 Dielectric Test Equipment	12-3
	12.4.2 Evaluation of Insulation Systems by a Dielectric Test	12-3
12.5	REPETITIVE SURGE TEST FOR SMALL AND MEDIUM MOTORS	12-3
12.6	MECHANICAL VIBRATION	12-4
12.7	BEARING LOSSES—VERTICAL PUMP MOTORS	12-4

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 12—TESTS AND PERFORMANCE—AC MOTORS

12.0	SCOPE	12-5
12.30	TEST METHODS	12-5
12.31	PERFORMANCE CHARACTERISTICS	12-5
12.32	TORQUE CHARACTERISTICS OF SINGLE-PHASE GENERAL- PURPOSE INDUCTION MOTORS	12-5
	12.32.1 Breakdown Torque	12-5
	12.32.2 Locked-rotor Torque of Small Motors	12-6
	12.32.3 Locked-rotor Torque of Medium Motors	12-6
	12.32.4 Pull-Up Torque of Medium Motors	12-6
12.33	LOCKED-ROTOR CURRENT OF SINGLE-PHASE SMALL MOTORS	12-6
	12.33.1 Design O and Design N Motors	12-6
	12.33.2 General-Purpose Motors	12-7
12.34	LOCKED-ROTOR CURRENT OF SINGLE-PHASE MEDIUM MOTORS, DESIGNS L AND M	12-7
12.35	LOCKED-ROTOR CURRENT OF 3-PHASE 60-HERTZ SMALL AND MEDIUM SQUIRREL-CAGE INDUCTION MOTORS RATED AT 230 VOLTS	12-7
	12.35.1 60-Hertz Design B, C, and D Motors at 230 Volts	12-7
	12.35.2 50-Hertz Design B, C, and D Motors at 380 Volts	12-9
12.36	INSTANTANEOUS PEAK VALUE OF INRUSH CURRENT	12-9
12.37	TORQUE CHARACTERISTICS OF POLYPHASE SMALL MOTORS	12-9
12.38	LOCKED-ROTOR TORQUE OF SINGLE-SPEED POLYPHASE SQUIRREL-CAGE MEDIUM MOTORS WITH CONTINUOUS RATINGS	12-10
	12.38.1 Design A and B Motors	12-10
	12.38.2 Design C Motors	12-10
	12.38.3 Design D Motors	12-11
12.39	BREAKDOWN TORQUE OF SINGLE-SPEED POLYPHASE SQUIRREL-CAGE MEDIUM MOTORS WITH CONTINUOUS RATINGS	12-11
	12.39.1 Design A and B Motors	12-11
	12.39.2 Design C Motors	12-11
12.40	PULL-UP TORQUE OF SINGLE-SPEED POLYPHASE SQUIRREL- CAGE MEDIUM MOTORS WITH CONTINUOUS RATINGS	12-12
	12.40.1 Design A and B Motors	12-12
	12.40.2 Design C Motors	12-13
12.41	BREAKDOWN TORQUE OF POLYPHASE WOUND-ROTOR MEDIUM MOTORS WITH CONTINUOUS RATINGS	12-13
12.42	TEMPERATURE RISE FOR SMALL AND UNIVERSAL MOTORS	12-14
	12.42.1 Alternating-Current Small Motors—Motor Nameplates	

	Marked with Insulation System Designation and Ambient Temperature.....	12-14
12.42.2	Universal Motors.....	12-15
12.42.3	Temperature Rise for Ambients Higher than 40°C.....	12-15
12.42.4	Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C but Not Below 0° C.....	12-16
12.43	TEMPERATURE RISE FOR MEDIUM SINGLE-PHASE AND POLYPHASE INDUCTION MOTORS.....	12-17
12.43.1	Temperature Rise for Ambients Higher than 40°C.....	12-17
12.43.2	Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C.....	12-18
12.44	VARIATION FROM RATED VOLTAGE AND RATED FREQUENCY.....	12-19
12.44.1	Running.....	12-19
12.44.2	Starting.....	12-19
12.45	VOLTAGE UNBALANCE.....	12-19
12.46	VARIATION FROM RATED SPEED.....	12-19
12.47	NAMEPLATE AMPERES—ALTERNATING-CURRENT MEDIUM MOTORS.....	12-19
12.48	OCCASIONAL EXCESS CURRENT.....	12-19
12.49	STALL TIME.....	12-20
12.50	PERFORMANCE OF MEDIUM MOTORS WITH DUAL VOLTAGE RATING (SUGGESTED STANDARD FOR FUTURE DESIGN).....	12-20
12.51	SERVICE FACTOR OF ALTERNATING-CURRENT MOTORS.....	12-20
12.51.1	General-Purpose Alternating-Current Motors of the Open Type.....	12-20
12.51.2	Other Motors.....	12-21
12.52	OVERSPEEDS FOR MOTORS.....	12-21
12.52.1	Squirrel-Cage and Wound-Rotor Motors.....	12-21
12.52.2	General-Purpose Squirrel-Cage Induction Motors.....	12-21
12.52.3	General-Purpose Design A and B Direct-Coupled Drive Squirrel-Cage Induction Motors.....	12-23
12.52.4	Alternating-Current Series and Universal Motors.....	12-23
12.53	MACHINE SOUND (MEDIUM INDUCTION MOTORS).....	12-25
12.54	NUMBER OF STARTS.....	12-25
12.54.1	Normal Starting Conditions.....	12-25
12.54.2	Other than Normal Starting Conditions.....	12-25
12.54.3	Considerations for Additional Starts.....	12-25
12.55	ROUTINE TESTS FOR POLYPHASE MEDIUM INDUCTION MOTORS.....	12-25
12.55.1	Method of Testing.....	12-25
12.55.2	Typical Tests on Completely Assembled Motors.....	12-26
12.55.3	Typical of Tests on Motors Not Completely Assembled.....	12-26
12.56	THERMAL PROTECTION OF MEDIUM MOTORS.....	12-27
12.56.1	Winding Temperature.....	12-27
12.56.2	Trip Current.....	12-29
12.57	OVERTEMPERATURE PROTECTION OF MEDIUM MOTORS NOT MEETING THE DEFINITION OF "THERMALLY PROTECTED".....	12-29
12.57.1	Type 1—Winding Running and Locked Rotor Overtemperature Protection.....	12-29
12.57.2	Type 2—Winding Running Overtemperature Protection.....	12-29
12.57.3	Type 3—Winding Overtemperature Protection, Nonspecific Type.....	12-29
12.58	EFFICIENCY.....	12-29
12.58.1	Determination of Motor Efficiency and Losses.....	12-29
12.58.2	Efficiency of Polyphase Squirrel-Cage Medium Motors with Continuous Ratings.....	12-30
12.59	EFFICIENCY LEVELS OF ENERGY EFFICIENT POLYPHASE SQUIRREL-CAGE INDUCTION MOTORS.....	12-31
12.60	EFFICIENCY LEVEL OF NEMA PREMIUM® EFFICIENCY ELECTRIC MOTORS.....	12-32

12.60.1	60 Hz Motors Rated 600 Volts or Less (Random Wound)	12-32
12.60.2	60 Hz Motors Rated Medium Voltage, 5000 Volts or Less (Form Wound)	12-32
12.60.3	50 Hz Motors Rated 400 Volts or Less (Random Wound)	12-32
12.61	REPORT OF TEST FOR TESTS ON INDUCTION MOTORS	12-32
	Table 12-11	12-33
	Table 12-12	12-35
	Table 12-13	12-37
	Table 12-14	12-38
12.62	MACHINE WITH ENCAPSULATED OR SEALED WINDING	
	CONFORMANCE TESTS	12-40
12.63	MACHINE WITH MOISTURE RESISTANT WINDINGS—	
	CONFORMANCE TEST	12-40

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 12—TESTS AND PERFORMANCE—DC SMALL AND MEDIUM MOTORS

12.0	SCOPE	12-41
12.65	TEST METHODS	12-41
12.66	TEST POWER SUPPLY	12-41
	12.66.1 Small Motors	12-41
	12.66.2 Medium Motors	12-41
12.67	TEMPERATURE RISE	12-43
	12.67.1 Direct-Current Small Motors	12-43
	12.67.2 Continuous-Time-Rated Direct-Current Medium Motors	12-43
	12.67.3 Short-Time-Rated Direct-Current Medium Motors	12-44
	12.67.4 Temperature Rise for Ambients Higher than 40°C	12-44
	12.67.5 Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C	12-45
12.68	VARIATION FROM RATED VOLTAGE	12-46
12.69	VARIATION IN SPEED DUE TO LOAD	12-46
	12.69.1 Straight-Shunt-Wound, Stabilized-Shunt-Wound, and Permanent-Magnet Direct-Current Motors	12-46
	12.69.2 Compound-Wound Direct-Current Motors	12-46
12.70	VARIATION IN BASE SPEED DUE TO HEATING	12-46
	12.70.1 Speed Variation with Temperature	12-46
	12.70.2 Resistance Variation with Temperature	12-47
12.71	VARIATION FROM RATED SPEED	12-47
12.72	MOMENTARY OVERLOAD CAPACITY	12-47
12.73	SUCCESSFUL COMMUTATION	12-47
12.74	OVERSPEEDS FOR MOTORS	12-47
	12.74.1 Shunt-Wound Motors	12-47
	12.74.2 Compound-Wound Motors Having Speed Regulation of 35 Percent or Less	12-47
	12.74.3 Series-Wound Motors and Compound-Wound Motors Having Speed Regulation Greater Than 35 Percent	12-47
12.75	FIELD DATA FOR DIRECT-CURRENT MOTORS	12-48
12.76	ROUTINE TESTS ON MEDIUM DIRECT-CURRENT MOTORS	12-48
12.77	REPORT OF TEST FORM FOR DIRECT-CURRENT MACHINES	12-48
12.78	EFFICIENCY	12-48
	12.78.1 Type A Power Supplies	12-48
	12.78.2 Other Power Supplies	12-49
12.79	STABILITY	12-49
12.80	OVER TEMPERATURE PROTECTION OF MEDIUM DIRECT- CURRENT MOTORS	12-49
12.81	DATA FOR DIRECT CURRENT MOTORS	12-50
12.82	MACHINE SOUND OF DIRECT-CURRENT MEDIUM MOTORS	12-51

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 13—FRAME ASSIGNMENTS FOR ALTERNATING CURRENT INTEGRAL HORSEPOWER INDUCTION MOTORS

13.0	SCOPE	13-1
13.1	FRAME DESIGNATIONS FOR SINGLE-PHASE DESIGN L, HORIZONTAL, AND VERTICAL MOTORS, 60 HERTZ CLASS B INSULATION SYSTEM, OPEN TYPE, 1.15 SERVICE FACTOR, 230 VOLTS AND LESS.....	13-1
13.2	FRAME DESIGNATIONS FOR POLYPHASE, SQUIRREL-CAGE, DESIGNS A, B, AND E, HORIZONTAL AND VERTICAL MOTORS, 60 HERTZ, CLASS B INSULATION SYSTEM, OPEN TYPE, 1.15 SERVICE FACTOR, 575 VOLTS AND LESS.....	13-2
13.3	FRAME DESIGNATIONS FOR POLYPHASE, SQUIRREL-CAGE, DESIGNS A, B, ND E, HORIZONTAL AND VERTICAL MOTORS, 60 HERTZ, CLASS B INSULATION SYSTEM, TOTALLY ENCLOSED FAN-COOLED TYPE, 1.0 SERVICE FACTOR, 575 VOLTS AND LESS	13-3
13.4	FRAME DESIGNATIONS FOR POLYPHASE, SQUIRREL-CAGE, DESIGN C, HORIZONTAL AND VERTICAL MOTORS, 60 HERTZ, CLASS B INSULATION SYSTEM, OPEN TYPE, 1.15 SERVICE FACTOR, 575 VOLTS AND LESS	13-4
13.5	FRAME DESIGNATIONS FOR POLYPHASE, SQUIRREL-CAGE, DESIGN C, HORIZONTAL AND VERTICAL MOTORS, 60 HERTZ, CLASS B INSULATION SYSTEM, TOTALLY ENCLOSED FAN- COOLED TYPE, 1.0 SERVICE FACTOR, 575 VOLTS AND LESS.....	13-5

SECTION II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 14—APPLICATION DATA—AC AND DC SMALL AND MEDIUM MACHINES

14.0	SCOPE	14-1
14.1	PROPER SELECTION OF APPARATUS	14-1
14.2	USUAL SERVICE CONDITIONS	14-2
	14.2.1 Environmental Conditions.....	14-2
	14.2.2 Operating Conditions	14-2
14.3	UNUSUAL SERVICE CONDITIONS	14-2
14.4	TEMPERATURE RISE	14-3
	14.4.1 Motors with Class A or Class B Insulation Systems.....	14-3
	14.4.2 Motors with Service Factor	14-3
	14.4.3 Temperature Rise at Sea Level.....	14-3
	14.4.4 Preferred Values of Altitude for Rating Motors	14-4
14.5	SHORT-TIME RATED ELECTRICAL MACHINES.....	14-4
14.6	DIRECTION OF ROTATION	14-4
14.7	APPLICATION OF PULLEYS, SHEAVES, SPROCKETS, AND GEARS ON MOTOR SHAFTS	14-4
	14.7.1 Mounting	14-4
	14.7.2 Minimum Pitch Diameter for Drives Other than V-Belt	14-4
	14.7.3 Maximum Speed of Drive Components.....	14-5
14.8	THROUGH-BOLT MOUNTING	14-5
14.9	RODENT PROTECTION	14-5

SECTION II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 14—APPLICATION DATA—AC SMALL AND MEDIUM MOTORS

14.0	SCOPE	14-7
14.30	EFFECTS OF VARIATION OF VOLTAGE AND FREQUENCY UPON THE PERFORMANCE OF INDUCTION MOTORS.....	14-7
	14.30.1 General	14-7
	14.30.2 Effects of Variation in Voltage on Temperature.....	14-7
	14.30.3 Effect of Variation in Voltage on Power Factor.....	14-7

14.30.4	Effect of Variation in Voltage on Starting Torques.....	14-7
14.30.5	Effect of Variation in Voltage on Slip	14-7
14.30.6	Effects of Variation in Frequency.....	14-8
14.30.7	Effect of Variations in Both Voltage and Frequency	14-8
14.30.8	Effect on Special-Purpose or Small Motors	14-8
14.31	MACHINES OPERATING ON AN UNDERGROUND SYSTEM	14-8
14.32	OPERATION OF ALTERNATING CURRENT MOTORS FROM VARIABLE-FREQUENCY OR VARIABLE-VOLTAGE POWER SUPPLIES, OR BOTH	14-8
14.32.1	Performance	14-8
14.32.2	Shaft Voltages.....	14-9
14.33	EFFECTS OF VOLTAGES OVER 600 VOLTS ON THE PERFORMANCE OF LOW-VOLTAGE MOTORS.....	14-9
14.34	OPERATION OF GENERAL-PURPOSE ALTERNATING-CURRENT POLYPHASE, 2-, 4-, 6-, AND 8-POLE, 60-HERTZ MEDIUM INDUCTION MOTORS OPERATED ON 50 HERTZ.....	14-9
14.34.1	Speed.....	14-9
14.34.2	Torques.....	14-9
14.34.3	Locked-Rotor Current	14-10
14.34.4	Service Factor.....	14-10
14.34.5	Temperature Rise	14-10
14.35	OPERATION OF 230-VOLT INDUCTION MOTORS ON 208-VOLT SYSTEMS.....	14-10
14.35.1	General	14-10
14.35.2	Nameplate Marking of Useable @ 200 V	14-10
14.35.3	Effect on Performance of Motor.....	14-10
14.36	EFFECTS OF UNBALANCED VOLTAGES ON THE PERFORMANCE OF POLYPHASE INDUCTION MOTORS	14-10
14.36.1	Effect on Performance—General.....	14-11
14.36.2	Unbalance Defined	14-11
14.36.3	Torques.....	14-11
14.36.4	Full-Load Speed	14-11
14.36.5	Currents	14-11
14.37	APPLICATION OF ALTERNATING-CURRENT MOTORS WITH SERVICE FACTORS	14-12
14.37.1	General	14-12
14.37.2	Temperature Rise—Medium Alternating-Current Motors.....	14-12
14.37.3	Temperature Rise—Small Alternating-Current Motors.....	14-12
14.38	CHARACTERISTICS OF PART-WINDING-START POLYPHASE INDUCTION MOTORS	14-12
14.39	COUPLING END-PLAY AND ROTOR FLOAT FOR HORIZONTAL ALTERNATING-CURRENT MOTORS	14-12
14.39.1	Preferred Hp Ratings for Motors with Ball Bearings	14-12
14.39.2	Limits for Motors with Sleeze Bearings	14-13
14.39.3	Drawing and Shaft Markings.....	14-13
14.40	OUTPUT SPEEDS FOR MEDIUM GEAR MOTORS OF PARALLEL CONSTRUCTION	14-14
14.41	APPLICATION OF MEDIUM ALTERNATING-CURRENT SQUIRREL- CAGE MACHINES WITH SEALED WINDINGS.....	14-14
14.41.1	Usual Service Conditions.....	14-14
14.41.2	Unusual Service Conditions.....	14-14
14.41.3	Hazardous Locations	14-15
14.42	APPLICATION OF V-BELT SHEAVES TO ALTERNATING CURRENT MOTORS HAVING ANTIFRICTION BEARINGS	14-15
14.42.1	Dimensions	14-15
14.42.2	Radial Overhung Load Limitations	14-15

14.43	ASEISMATIC CAPABILITY	14-15
14.44	POWER FACTOR OF THREE-PHASE, SQUIRREL-CAGE, MEDIUM MOTORS WITH CONTINUOUS RATINGS.....	14-17
14.44.1	Determination of Power Factor from Nameplate Data.....	14-17
14.44.2	Determination of Capacitor Rating for Connecting Power Factor to Desired Value	14-17
14.44.3	Determination of Corrected Power Factor for Specified Capacitor Rating	14-18
14.44.4	Application of Power Factor Correction Capacitors on Power Systems.....	14-18
14.44.5	Application of Power Factor Correction Capacitors on Motors Operated from Electronic Power Supply.....	14-18
14.45	BUS TRANSFER OR RECLOSING	14-18
14.46	ROTOR INERTIA FOR DYNAMIC BREAKING.....	14-18
14.47	EFFECTS OF LOAD ON MOTOR EFFICIENCY	14-18

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 14—APPLICATION DATA—DC SMALL AND MEDIUM MOTORS

14.0	SCOPE	14-21
14.60	OPERATION OF SMALL MOTORS ON RECTIFIED ALTERNATING CURRENT	14-21
14.60.1	General	14-21
14.60.2	Form Factor	14-21
14.61	OPERATION OF DIRECT-CURRENT MEDIUM MOTORS ON RECTIFIED ALTERNATING CURRENT	14-22
14.62	ARMATURE CURRENT RIPPLE	14-23
14.63	OPERATION ON A VARIABLE-VOLTAGE POWER SUPPLY	14-23
14.64	SHUNT FIELD HEATING AT STANDSTILL.....	14-24
14.65	BEARING CURRENTS.....	14-24
14.66	EFFECTS OF 50-HERTZ ALTERNATING-CURRENT POWER FREQUENCY	14-24
14.67	APPLICATION OF OVERHUNG LOADS TO MOTOR SHAFTS	14-25
14.67.1	Limitations.....	14-25
14.67.2	V-Belt Drives	14-26
14.67.3	Applications Other Than V-Belts.....	14-27
14.67.4	General	14-27
14.68	RATE OF CHANGE OF ARMATURE CURRENT	14-28

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 15—DC Generators

15.0	SCOPE	15-1
15.10	KILOWATT, SPEED, AND VOLTAGE RATINGS	15-1
15.10.1	Standard Ratings	15-1
15.10.2	Exciters	15-2
15.11	NAMEPLATE TIME RATING, MAXIMUM AMBIENT TEMPERATURE, AND INSULATION SYSTEM CLASS	15-2
15.12	NAMEPLATE MARKING	15-2
TESTS AND PERFORMANCE		15-2
15.40	TEST PERFORMANCE.....	15-2
15.41	TEMPERATURE RISE	15-2
15.41.1	Temperature Rise for Maximum Ambient of 40°C.....	15-2
15.41.2	Temperature Rise for Ambients Higher than 40°C	15-3
15.41.3	Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C.....	15-3
15.42	SUCCESSFUL COMMUTATION	15-4
15.43	OVERLOAD	15-4
15.44	VOLTAGE VARIATION DUE TO HEATING.....	15-4

15.45	FLAT COMPOUNDING	15-4
15.46	TEST FOR REGULATION	15-4
15.47	OVERSPEEDS FOR GENERATORS	15-5
15.48	HIGH-POTENTIAL TEST	15-5
	15.48.1 Safety Precautions for Test Procedure	15-5
	15.48.2 Test Voltage	15-5
15.49	ROUTINE TESTS	15-5
15.50	FIELD DATA FOR DIRECT-CURRENT GENERATORS	15-5
15.51	REPORT OF TEST FORM	15-6
15.52	EFFICIENCY	15-6
	MANUFACTURING	15-7
15.60	DIRECTION OF ROTATION	15-7
15.61	EQUALIZER LEADS OF DIRECT-CURRENT GENERATORS	15-7

Section II SMALL (FRACTIONAL) AND MEDIUM (INTEGRAL) MACHINES

Part 18—DEFINITE PURPOSE MACHINES

18.1	SCOPE	18-1
	MOTORS FOR HERMETIC REFRIGERATION COMPRESSORS	18-1
18.2	CLASSIFIED ACCORDING TO ELECTRICAL TYPE	18-2
	RATINGS	18-3
18.3	VOLTAGE RATINGS	18-3
	18.3.1 Single-Phase Motors	18-3
	18.3.2 Polyphase Induction Motors	18-3
18.4	FREQUENCIES	18-3
18.5	SPEED RATINGS	18-3
	TESTS AND PERFORMANCE	18-3
18.6	OPERATING TEMPERATURE	18-3
18.7	BREAKDOWN TORQUE AND LOCKED-ROTOR CURRENT OF 60-HERTZ HERMETIC MOTORS	18-3
	18.7.1 Breakdown Torque	18-3
	18.7.2 Locked-Rotor Current	18-3
18.8	HIGH-POTENTIAL TEST	18-5
18.9	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-5
18.10	DIRECTION OF ROTATION	18-5
18.11	TERMINAL LEAD MARKINGS	18-5
18.12	METHOD TEST FOR CLEANLINESS OF SINGLE-PHASE HERMETIC MOTORS HAVING STATOR DIAMETERS OF 6.292 INCHES AND SMALLER	18-5
	18.12.1 Stators	18-6
	18.12.2 Rotors	18-6
18.13	METHOD OF TEST FOR CLEANLINESS OF HERMETIC MOTORS HAVING STATOR DIAMETERS OF 8.777 INCHES AND SMALLER	18-6
	18.13.1 Purpose	18-6
	18.13.2 Description	18-6
	18.13.3 Sample Storage	18-6
	18.13.4 Equipment	18-6
	18.13.5 Procedure	18-7
	MANUFACTURING	18-7
18.14	ROTOR BORE DIAMETERS AND KEYWAY DIMENSIONS FOR 60-HERTZ HERMETIC MOTORS	18-8
18.15	DIMENSIONS FOR 60-HERTZ HERMETIC MOTORS	18-9
18.16	FORMING OF END WIRE	18-9
18.17	THERMAL PROTECTORS ASSEMBLED ON OR IN END WINDINGS OF HERMETIC MOTORS	18-9
18.18	LETTERING OF DIMENSIONS FOR HERMETIC MOTORS	

FOR HERMETIC COMPRESSORS	18-10
SMALL MOTORS FOR SHAFT-MOUNTED FANS AND BLOWERS	18-12
18.19 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-12
RATINGS	18-12
18.20 VOLTAGE RATINGS	18-12
18.20.1 Single-Phase Motors	18-12
18.20.2 Polyphase Induction Motors	18-12
18.21 FREQUENCIES	18-12
18.22 HORSEPOWER AND SPEED RATINGS	18-12
18.22.1 Single-Speed Motors	18-12
18.22.2 Two-Speed Motors	18-12
TESTS AND PERFORMANCE	18-13
18.23 TEMPERATURE RISE	18-13
18.24 BASIS OF HORSEPOWER RATING	18-13
18.25 MAXIMUM LOCKED-ROTOR CURRENT—SINGLE-PHASE	18-13
18.26 HIGH-POTENTIAL TESTS	18-13
18.27 VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-13
18.28 DIRECTION OF ROTATION	18-13
MANUFACTURING	18-13
18.29 GENERAL MECHANICAL FEATURES	18-13
18.30 DIMENSIONS AND LETTERING OF DIMENSIONS FOR MOTORS FOR SHAFT-MOUNTED FANS AND BLOWERS	18-13
18.31 TERMINAL MARKINGS	18-13
18.32 TERMINAL LEAD LENGTHS	18-14
SMALL MOTORS FOR BELTED FANS AND BLOWERS BUILT IN FRAMES 56 AND SMALLER	18-16
18.33 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-16
RATINGS	18-16
18.34 VOLTAGE RATINGS	18-16
18.34.1 Single-Phase Motors	18-16
18.34.2 Polyphase Motors	18-16
18.35 FREQUENCIES	18-16
18.36 HORSEPOWER AND SPEED RATINGS	18-16
18.36.1 Single-Speed Motors	18-16
18.36.2 Two-Speed Motors	18-16
TESTS AND PERFORMANCE	18-17
18.37 TEMPERATURE RISE	18-17
18.38 BASIS OF HORSEPOWER RATING	18-17
18.39 MAXIMUM LOCKED-ROTOR CURRENT	18-17
18.40 HIGH-POTENTIAL TEST	18-17
18.41 VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-17
18.42 DIRECTION OF ROTATION	18-17
MANUFACTURING	18-17
18.43 GENERAL MECHANICAL FEATURES	18-17
18.44 LETTERING OF DIMENSIONS FOR MOTORS FOR BELTED FANS AND BLOWERS	18-18
SMALL MOTORS FOR AIR CONDITIONING CONDENSERS AND EVAPORATOR FANS	18-19
18.45 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-19
RATINGS	18-19
18.46 VOLTAGE RATINGS	18-19
18.47 FREQUENCIES	18-19
18.48 HORSEPOWER AND SPEED RATINGS	18-19
18.48.1 Horsepower Ratings	18-19
18.48.2 Speed Ratings	18-19
TESTS AND PERFORMANCE	18-19

18.49	TEMPERATURE RISE	18-19
18.50	BASIS OF HORSEPOWER RATINGS.....	18-19
18.51	HIGH-POTENTIAL TESTS	18-20
18.52	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-20
18.53	VARIATION FROM RATED SPEED	18-20
18.54	TERMINAL MARKINGS—MULTISPEED SHADED-POLE MOTORS.....	18-20
	MANUFACTURING	18-20
18.55	TERMINAL MARKINGS.....	18-20
18.56	TERMINAL LEAD LENGTHS	18-21
18.57	GENERAL MECHANICAL FEATURES.....	18-21
18.58	TERMINAL MARKINGS FOR NON-POLE-CHANGING MULTISPEED SINGLE-VOLTAGE NONREVERSIBLE PERMANENT-SPLIT CAPACITOR MOTORS AND SHADED POLE MOTORS.....	18-22
18.59	DIMENSIONS OF SHADED-POLE AND PERMANENT-SPLIT CAPACITOR MOTORS HAVING A P DIMENSION 4.38 INCHES AND LARGER	18-24
18.60	DIMENSIONS OF SHADED-POLE AND PERMANENT SPLIT CAPACITOR MOTORS HAVING A P DIMENSION SMALLER THAN 4.38 INCHES	18-25
18.61	DIMENSIONS FOR LUG MOUNTING FOR SHADED-POLE AND PERMANENT-SPLIT CAPACITOR MOTORS	18-25
	APPLICATION DATA	18-26
18.62	NAMEPLATE CURRENT.....	18-26
	RATINGS	18-26
18.63	EFFECT OF VARIATION FROM RATED VOLTAGE UPON OPERATING SPEED.....	18-26
18.64	INSULATION TESTING.....	18-26
	18.64.1 Test Conditions	18-26
	18.64.2 Test Method	18-27
18.65	SERVICE CONDITIONS.....	18-27
	SMALL MOTORS AND SUMP PUMPS	18-30
18.66	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-30
	RATINGS	18-30
18.67	VOLTAGE RATINGS	18-30
18.68	FREQUENCIES	18-30
18.69	HORSEPOWER AND SPEED RATINGS.....	18-30
	18.69.1 Horsepower Ratings	18-30
	18.69.2 Speed Ratings	18-30
	TESTS AND PERFORMANCE	18-30
18.70	TEMPERATURE RISE	18-30
18.71	BASIS OF HORSEPOWER RATINGS.....	18-30
18.72	TORQUE CHARACTERISTICS	18-30
18.73	HIGH-POTENTIAL TESTS	18-31
18.74	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-31
18.75	DIRECTION OF ROTATION	18-31
	MANUFACTURING	18-31
18.76	GENERAL MECHANICAL FEATURES.....	18-31
18.77	DIMENSIONS FOR SUMP PUMP MOTORS, TYPE K.....	18-31
18.78	FRAME NUMBER AND FRAME SUFFIX LETTER.....	18-31
	SMALL MOTORS FOR GASOLINE DISPENSING PUMPS	18-33
18.79	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-33
	RATINGS	18-33
18.80	VOLTAGE RATINGS	18-33
	18.80.1 Single-Phase Motors	18-33
	18.80.2 Polyphase Induction Motors	18-33

18.81	FREQUENCIES	18-33
18.82	HORSEPOWER AND SPEED RATINGS.....	18-32
18.82.1	Horsepower Ratings	18-32
18.82.2	Speed Ratings	18-33
TESTS AND PERFORMANCE		18-33
18.83	TEMPERATURE RISE	18-33
18.84	BASIS OF HORSEPOWER RATINGS.....	18-34
18.85	LOCKED-ROTOR TORQUE	18-34
18.86	LOCKED-ROTOR CURRENT	18-34
18.87	HIGH-POTENTIAL TEST	18-35
18.88	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-35
18.89	DIRECTION OF ROTATION	18-35
MANUFACTURING		18-35
18.90	GENERAL MECHANICAL FEATURES.....	18-35
18.91	FRAME NUMBER AND FRAME SUFFIX LETTER.....	18-35
18.92	DIMENSIONS FOR GASOLINE DISPENSING PUMP MOTORS, TYPE G.....	18-36
SMALL MOTORS FOR OIL BURNERS		18-37
18.93	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-37
RATINGS		18-37
18.94	VOLTAGE RATINGS	18-37
18.95	FREQUENCIES	18-37
18.96	HORSEPOWER AND SPEED RATINGS.....	18-37
18.96.1	Horsepower Ratings	18-37
18.96.2	Speed Ratings	18-37
TESTS AND PERFORMANCE		18-37
18.97	TEMPERATURE RISE	18-37
18.98	BASIS OF HORSEPOWER RATING	18-38
18.99	LOCKED-ROTOR CHARACTERISTICS.....	18-38
18.100	HIGH-POTENTIAL TEST	18-38
18.101	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-38
18.102	DIRECTION OF ROTATION	18-38
MANUFACTURING		18-38
18.103	GENERAL MECHANICAL FEATURES.....	18-38
18.104	DIMENSIONS FOR FACE-MOUNTING MOTORS FOR OIL- BURNERS, TYPES M AND N	18-39
18.104.1	Dimensions	18-39
18.105	TOLERANCES.....	18-39
18.106	FRAME NUMBER AND FRAME SUFFIX LETTER.....	18-39
18.106.1	Suffix Letter M.....	18-39
18.106.2	Suffix Letter N	18-40
SMALL MOTORS FOR HOME LAUNDRY EQUIPMENT		18-41
18.107	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-41
RATINGS		18-41
18.108	VOLTAGE RATINGS	18-41
18.109	FREQUENCIES	18-41
18.110	HORSEPOWER AND SPEED RATINGS.....	18-41
18.110.1	Horsepower Ratings	18-41
18.110.2	Speed Ratings	18-41
18.111	NAMEPLATE MARKING	18-41
TESTS AND PERFORMANCE		18-42
18.112	TEMPERATURE RISE	18-42
18.113	BASIS OF HORSEPOWER RATING	18-42
18.114	MAXIMUM LOCKED-ROTOR CURRENT.....	18-42
18.115	HIGH-POTENTIAL TEST	18-42

18.116	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-42
MANUFACTURING		18-42
18.117	GENERAL MECHANICAL FEATURES	18-42
18.118	DIMENSIONS FOR MOTORS FOR HOME LAUNDRY EQUIPMENT	18-43
MOTORS AND JET PUMPS		18-44
18.119	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-44
RATINGS		18-44
18.120	VOLTAGE RATINGS	18-44
18.120.1	Single-Phase Motors	18-44
18.120.2	Polyphase Induction Motors	18-44
18.121	FREQUENCIES	18-44
18.122	HORSEPOWER, SPEED, AND SERVICE FACTOR RATINGS	18-44
TEST AND PERFORMANCE		18-45
18.123	TEMPERATURE RISE	18-45
18.124	BASIS OF HORSEPOWER RATING	18-45
18.125	TORQUE CHARACTERISTICS	18-45
18.126	MAXIMUM LOCKED-ROTOR CURRENT	18-45
18.127	HIGH-POTENTIAL TEST	18-45
18.128	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-45
18.129	DIRECTION OF ROTATION	18-45
MANUFACTURING		18-45
18.130	GENERAL MECHANICAL FEATURES	18-45
18.131	DIMENSION FOR FACE-MOUNTED MOTORS FOR JET PUMPS	18-46
18.132	FRAME NUMBER AND FRAME SUFFIX LETTER	18-47
SMALL MOTORS FOR COOLANT PUMPS		18-48
18.133	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-48
RATINGS		18-48
18.134	VOLTAGE RATINGS	18-48
18.134.1	Single-Phase Motors	18-48
18.134.2	Polyphase Induction Motors	18-48
18.134.3	Direct-current Motors	18-48
18.135	FREQUENCIES	18-48
18.136	HORSEPOWER AND SPEED RATINGS	18-49
TESTS AND PERFORMANCE		18-50
18.137	TEMPERATURE RISE	18-50
18.138	BASIS OF HORSEPOWER RATING	18-50
18.139	TORQUE CHARACTERISTICS	18-50
18.140	MAXIMUM LOCKED-ROTOR CURRENT	18-50
18.141	HIGH-POTENTIAL TEST	18-50
18.142	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-50
18.143	DIRECTION OF ROTATION	18-50
MANUFACTURING		18-51
18.144	GENERAL MECHANICAL FEATURES	18-51
SUBMERSIBLE MOTORS FOR DEEP WELL PUMPS—4-INCH		18-52
18.145	CLASSIFICATION TO ELECTRICAL TYPE	18-52
RATINGS		18-52
18.146	VOLTAGE RATINGS	18-52
18.146.1	Single-Phase Motors	18-52
18.146.2	Polyphase Induction Motors	18-52
18.147	FREQUENCIES	18-52
18.148	HORSEPOWER AND SPEED RATINGS	18-52
18.148.1	Horsepower Ratings	18-52
18.148.2	Speed Ratings	18-52
TESTS AND PERFORMANCE		18-53
18.149	BASIS OF HORSEPOWER RATING	18-53
18.150	LOCKED-ROTOR CURRENT	18-53

18.150.1 Single-Phase Small Motors	18-53
18.150.2 Single-Phase Medium Motors.....	18-53
18.152.3 Three-Phase Medium Motors	18-53
18.151 HIGH-POTENTIAL TEST	18-53
18.152 VARIATION FROM RATED VOLTAGE AT CONTROL BOX.....	18-53
18.153 VARIATION FROM RATED FREQUENCY	18-53
18.154 DIRECTION OF ROTATION	18-53
18.155 THRUST CAPACITY	18-53
MANUFACTURING	18-53
18.156 TERMINAL LEAD MARKINGS	18-53
18.157 GENERAL MECHANICAL FEATURES.....	18-54
SUBMERSIBLE MOTORS FOR DEEP WELL PUMPS—6-INCH	18-55
18.158 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-55
RATINGS	18-55
18.159 VOLTAGE RATINGS	18-55
18.159.1 Single-Phase Motors	18-55
18.159.2 Polyphase Induction Motors	18-55
18.160 FREQUENCIES	18-55
18.161 HORSEPOWER AND SPEED RATINGS.....	18-55
18.161.1 Horsepower Ratings	18-55
TESTS AND PERFORMANCE	18-55
18.162 BASIS FOR HORSEPOWER RATING.....	18-55
18.163 LOCKED-ROTOR CURRENT	18-55
18.164 HIGH-POTENTIAL TESTS	18-56
18.165 VARIATION FROM RATED VOLTAGE AT CONTROL BOX.....	18-56
18.166 VARIATION FROM RATED FREQUENCY	18-56
18.167 DIRECTION OF ROTATION	18-56
18.168 THRUST CAPACITY	18-56
MANUFACTURING	18-56
18.169 TERMINAL LEAD MARKINGS	18-56
18.170 GENERAL-MECHANICAL FEATURES.....	18-57
SUBMERSIBLE MOTORS FOR DEEP WELL PUMPS—8-INCH	18-58
18.171 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-58
RATINGS	18-58
18.172 VOLTAGE RATINGS	18-58
18.173 FREQUENCIES	18-58
18.174 HORSEPOWER AND SPEED RATINGS.....	18-58
18.174.1 Horsepower Ratings	18-58
18.174.2 Speed Ratings	18-58
TESTS AND PERFORMANCE	18-58
18.175 LOCKED-ROTOR CURRENT	18-58
18.176 HIGH-POTENTIAL TEST	18-58
18.177 VARIATION FROM RATED VOLTAGE AT CONTROL BOX.....	18-59
18.178 VARIATION FROM RATED FREQUENCY	18-59
18.179 DIRECTION OF ROTATION	18-59
18.180 THRUST CAPACITY	18-59
18.181 GENERAL MECHANICAL FEATURES.....	18-60
MEDIUM DC ELEVATOR MOTORS	18-61
18.182 CLASSIFICATION ACCORDING TO TYPE.....	18-61
18.182.1 Class DH.....	18-61
18.182.2 Class DL	18-61
RATINGS	18-61
18.183 VOLTAGE RATINGS	18-61
18.184 HORSEPOWER AND SPEED RATINGS.....	18-61
18.184.1 Class DH.....	18-61
18.184.2 Class DL	18-61

18.185	BASIS OF RATING	18-62
18.185.1	Class DH.....	18-62
18.185.2	Class DL	18-62
18.186	NAMEPLATE MARKINGS	18-62
TESTS AND PERFORMANCE		18-62
18.187	ACCELERATION AND DECELERATION CAPACITY	18-62
18.188	VARIATION IN SPEED DUE TO LOAD	18-62
18.188.1	Class DH.....	18-62
18.188.2	Class DL	18-62
18.189	VARIATION FROM RATED SPEED	18-62
18.190	VARIATION IN SPEED DUE TO HEATING	18-62
18.190.1	Open-Loop Control System	18-62
18.190.2	Closed-Loop Control System.....	18-63
18.191	HIGH-POTENTIAL TEST	18-63
18.192	TEMPERATURE RISE	18-63
MOTOR-GENERATOR SETS FOR DC ELEVATOR MOTORS		18-64
RATINGS		18-64
18.193	BASIS OF RATING	18-64
18.193.1	Time Rating.....	18-64
18.193.2	Relation to Elevator Motor	18-64
18.194	GENERATOR VOLTAGE RATINGS	18-64
18.194.1	Value.....	18-64
18.194.2	Maximum Value	18-64
TESTS AND PERFORMANCE		18-64
18.195	VARIATION IN VOLTAGE DUE TO HEATING	18-64
18.195.1	Open-Loop Control System	18-64
18.195.2	Closed-Loop Control System.....	18-64
18.196	OVERLOAD	18-64
18.197	HIGH-POTENTIAL TEST	18-65
18.198	VARIATION FROM RATED VOLTAGE.....	18-65
18.199	VARIATION FROM RATED FREQUENCY	18-65
18.200	COMBINED VARIATION OF VOLTAGE AND FREQUENCY.....	18-65
18.201	TEMPERATURE RISE	18-65
18.201.1	Induction Motors	18-65
18.201.2	Direct-Current Adjustable-Voltage Generators.....	18-65
MEDIUM AC POLYPHASE ELEVATOR MOTORS		18-66
18.202	CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-66
18.202.1	AH1	18-65
18.202.2	AH2	18-66
18.202.3	AH3	18-66
RATINGS		18-66
18.203	BASIS OF RATING—ELEVATOR MOTORS	18-66
18.204	VOLTAGE RATINGS	18-66
18.205	FREQUENCY	18-66
18.206	HORSEPOWER AND SPEED RATINGS.....	18-67
TESTS AND PERFORMANCE		18-67
18.207	LOCKED-ROTOR TORQUE FOR SINGLE-SPEED SQUIRREL- CAGE ELEVATOR MOTORS.....	18-67
18.208	TIME-TEMPERATURE RATING	18-67
18.209	HIGH-POTENTIAL TEST	18-67
18.210	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-67
MANUFACTURING		18-68
18.211	NAMEPLATE MARKING	18-68
MEDIUM AC CRANE MOTORS		18-69
RATINGS		18-69
18.212	VOLTAGE RATINGS	18-69

18.213	FREQUENCIES	18-69
18.214	HORSEPOWER AND SPEED RATINGS.....	18-69
18.215	SECONDARY DATA FOR WOUND-ROTOR CRANE MOTORS.....	18-70
18.216	NAMEPLATE MARKING	18-70
18.217	FRAME SIZES FOR TWO- AND THREE-PHASE 60-HERTZ OPEN AND TOTALLY ENCLOSED WOUND-ROTOR CRANE MOTORS HAVING CLASS B INSULATION SYSTEMS	18-71
TESTS AND PERFORMANCE		18-71
18.218	TIME RATINGS	18-71
18.219	TEMPERATURE RISE	18-71
18.220	BREAKDOWN TORQUE	18-71
	18.220.1 Minimum Value	18-71
	18.221.2 Maximum Value	18-71
18.222	HIGH-POTENTIAL TEST	18-71
18.223	OVERSPEEDS	18-72
18.224	PLUGGING	18-72
18.225	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-72
18.226	ROUTINE TESTS	18-72
18.227	BALANCE OF MOTORS	18-72
18.228	BEARINGS	18-72
18.229	DIMENSIONS FOR ALTERNATING-CURRENT WOUND-ROTOR OPEN AND TOTALLY ENCLOSED CRANE MOTORS.....	18-73
18.230	DIMENSIONS AND TOLERANCES FOR ALTERNATING- CURRENT OPEN AND TOTALLY ENCLOSED WOUND-ROTOR CRANE MOTORS HAVING ANTIFRICTION BEARINGS.....	18-74
MEDIUM SHELL-TYPE MOTORS FOR WOODWORKING AND MACHINE-TOOL APPLICATIONS		18-76
18.231	DEFINITION OF SHELL-TYPE MOTOR.....	18-76
18.232	TEMPERATURE RISE—SHELL-TYPE MOTOR	18-76
18.233	TEMPERATURE RISE FOR 60-HERTZ SHELL-TYPE MOTORS OPERATED ON 50-HERTZ	18-76
18.234	OPERATION AT OTHER FREQUENCIES—SHELL-TYPE MOTORS.....	18-76
18.235	RATINGS AND DIMENSIONS FOR SHELL-TYPE MOTORS.....	18-76
	18.235.1 Rotor Bore and Keyway Dimensions, Three-Phase 60-Hertz 40°C Open Motors, 208, 220, 440, and 550 Volts	18-76
	18.235.2 BH and BJ Dimensions in Inches, Open Type Three-Phase 60-Hertz 40°C Continuous, 208, 220, 440, and 550 Volts.....	18-77
18.236	LETTERING FOR DIMENSION SHEETS FOR SHELL-TYPE MOTORS	18-78
MEDIUM AC SQUIRREL-CAGE INDUCTION MOTORS FOR VERTICAL TURBINE PUMP APPLICATIONS.....		18-78
18.237	DIMENSION FOR TYPE VP VERTICAL SOLID-SHAFT, SINGLE-PHASE AND POLYPHASE, DIRECT CONNECTED SQUIRREL-CAGE INDUCTION MOTORS FOR VERTICAL TURBINE PUMP APPLICATIONS.....	18-79
18.238	DIMENSIONS FOR TYPE P AND PH ALTERNATING-CURRENT SQUIRREL-CAGE VERTICAL HOLLOW-SHAFT MOTORS FOR VERTICAL TURBINE PUMP APPLICATIONS.....	18-81
	18.238.1 Base Dimensions.....	18-81
	18.238.2 Coupling Dimensions.....	18-82
MEDIUM AC SQUIRREL-CAGE INDUCTION MOTORS FOR CLOSE-COUPLED PUMPS		18-83
RATINGS		18-83
18.239	VOLTAGE RATINGS	18-83
18.240	FREQUENCIES.....	18-83
18.241	NAMEPLATE MARKINGS.....	18-83
18.242	NAMEPLATE RATINGS	18-83

TESTS AND PERFORMANCE	18-83
18.243 TEMPERATURE RISE	18-83
18.244 TORQUES	18-83
18.245 LOCKED-ROTOR CURRENTS.....	18-83
18.246 HIGH-POTENTIAL TEST	18-83
18.247 VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-83
18.248 BALANCE OF MOTORS	18-83
MANUFACTURING	18-83
18.249 FRAME ASSIGNMENTS	18-83
18.250 DIMENSIONS FOR TYPE JM AND JP ALTERNATING-CURRENT FACE-MOUNTING CLOSE-COUPLED PUMP MOTORS HAVING ANTIFRICTION BEARINGS	18-84
18.251 DIMENSIONS FOR TYPE LP AND LPH VERTICAL SOLID-SHAFT SINGLE-PHASE AND POLYPHASE DIRECT-CONNECTED SQUIRREL- CAGE INDUCTION MOTORS (HAVING THE THRUST BEARING IN THE MOTOR) FOR CHEMICAL PROCESS IN-LINE PUMP APPLICATIONS.....	18-89
18.252 DIMENSIONS FOR TYPE HP AND HPH VERTICAL SOLID-SHAFT SINGLE-PHASE AND POLYPHASE DIRECT-CONNECTED SQUIRREL-CAGE INDUCTION MOTORS FOR PROCESS AND IN-LINE PUMP APPLICATIONS	18-91
DC PERMANENT-MAGNET TACHOMETER GENERATORS FOR CONTROL SYSTEMS	18-93
18.253 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-93
18.254 CLASSIFICATION ACCORDING TO OUTPUT VOLTAGE RATING	18-93
RATINGS	18-93
18.255 OUTPUT VOLTAGE RATINGS	18-93
18.256 CURRENT RATING	18-93
18.257 SPEED RATINGS	18-93
TESTS AND PERFORMANCE	18-93
18.258 TEST METHODS.....	18-93
18.259 TEMPERATURE RISE	18-93
18.260 VARIATION FROM RATED OUTPUT VOLTAGE.....	18-94
18.260.1 High-Voltage Type	18-94
18.260.2 Low-Voltage Type	18-94
18.261 HIGH-POTENTIAL TESTS	18-94
18.261.1 Test	18-94
18.261.2 Application	18-94
18.262 OVERSPEED.....	18-94
18.263 PERFORMANCE CHARACTERISTICS.....	18-94
18.263.1 High-Voltage Type	18-94
18.263.2 Low-Voltage Type	18-95
MANUFACTURING	18-95
18.264 NAMEPLATE MARKING	18-95
18.264.1 High-Voltage Type	18-95
18.264.2 Low-Voltage Type	18-95
18.265 DIRECTION OF ROTATION	18-95
18.266 GENERAL MECHANICAL FEATURES.....	18-95
18.266.1 High-Voltage Type	18-96
18.266.2 Low-Voltage Type	18-96
18.267 TERMINAL MARKINGS.....	18-96
TORQUE MOTORS	18-97
18.268 DEFINITION.....	18-97
18.269 NAMEPLATE MARKINGS	18-97
18.269.1 AC Torque Motors	18-97
18.269.2 DC Torque Motors	18-97
SMALL MOTORS FOR CARBONATOR PUMPS	18-98
18.270 CLASSIFICATION ACCORDING TO ELECTRICAL TYPE	18-98

RATINGS	18-98
18.271 VOLTAGE RATINGS	18-98
18.272 FREQUENCIES	18-98
18.273 HORSEPOWER AND SPEED RATING	18-98
18.273.1 Horsepower Ratings	18-98
18.273.2 Speed Ratings	18-98
TESTS AND PERFORMANCE	18-98
18.274 TEMPERATURE RISE	18-98
18.275 BASIS OF HORSEPOWER RATING	18-98
18.276 HIGH-POTENTIAL TEST	18-98
18.277 MAXIMUM LOCKED-ROTOR CURRENT—SINGLE PHASE	18-98
18.278 VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	18-98
18.279 DIRECTION OF ROTATION	18-98
MANUFACTURING	18-99
18.280 GENERAL MECHANICAL FEATURE	18-99
18.281 DIMENSIONS FOR CARBONATOR PUMP MOTORS	18-99

Section III LARGE MACHINES

Part 20—LARGE MACHINES—INDUCTION MACHINES

20.1 SCOPE	20-1
20.2 BASIS OF RATING	20-1
20.3 MACHINE POWER AND SPEED RATINGS	20-1
20.4 POWER RATINGS OF MULTISPEED MACHINES	20-2
20.4.1 Constant Power	20-2
20.4.2 Constant Torque	20-2
20.4.3 Variable Torque	20-2
20.5 VOLTAGE RATINGS	20-3
20.6 FREQUENCIES	20-3
20.7 SERVICE FACTOR	20-3
20.7.1 Service Factor of 1.0	20-3
20.7.2 Service Factor of 1.15	20-3
20.7.3 Application of Motors with a Service Factor of 1.15	20-3
TESTS AND PERFORMANCE	20-4
20.8 TEMPERATURE RISE	20-4
20.8.1 Machines with a 1.0 Service Factor at Rated Load	20-4
20.8.2 Machines with a 1.15 Service Factor at Service Factor Load	20-5
20.8.3 Temperature Rise for Ambients Higher than 40°C	20-5
20.8.4 Temperature Rise for Altitudes Greater than 3300 Feet (1000 Meters)	20-5
20.8.5 Temperature Rise for Air-Cooled Machines for Ambients Lower than 40°C, but Not Below 0°C	20-5
20.9 CODE LETTERS (FOR LOCKED-ROTOR KVA)	20-6
20.10 TORQUE	20-7
20.10.1 Standard Torque	20-7
20.10.2 High Torque	20-8
20.10.3 Motor Torques When Customer Specifies A Custom Load Curve	20-8
20.10.4 Motor With 4.5 pu and Lower Locked-Rotor Current	20-8
20.11 LOAD WK ² FOR POLYPHASE SQUIRREL-CASE INDUCTION MOTORS	20-8
20.12 NUMBER OF STARTS	20-9
20.12.1 Starting Capability	20-9
20.12.2 Additional Starts	20-9
20.12.3 Information Plate	20-9
20.13 OVERSPEEDS	20-9
20.14 VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	20-11
20.14.1 Running	20-11

20.14.2	Starting.....	20-11
20.15	OPERATION OF INDUCTION MACHINES FROM VARIABLE-FREQUENCY OR VARIABLE-VOLTAGE POWER SUPPLIES, OR BOTH.....	20-11
20.16	TESTS	20-12
20.16.1	Test Methods	20-12
20.16.2	Routine Tests on Machines Completely Assembled in Factory	20-12
20.16.3	Routine Tests on Machines Not Completely Assembled in Factory.....	20-12
20.17	HIGH-POTENTIAL TESTS	20-12
20.17.1	Safety Precautions and Test Procedure.....	20-12
20.17.2	Test Voltage—Primary Windings	20-12
20.17.3	Test Voltage—Secondary Windings of Wound Rotors.....	20-12
20.18	MACHINE WITH SEALED WINDINGS—CONFORMANCE TESTS	20-13
20.18.1	Test for Stator Which Can be Submerged.....	20-13
20.18.2	Test for Stator Which Cannot be Submerged.....	20-13
20.19	MACHINE SOUND	20-13
20.20	REPORT OF TEST FORM FOR INDUCTION MACHINES	20-14
20.21	EFFICIENCY.....	20-14
20.22	MECHANICAL VIBRATION.....	20-14
20.23	REED FREQUENCY OF VERTICAL MACHINES	20-15
20.24	EFFECTS OF UNBALANCED VOLTAGES ON THE PERFORMANCE OF POLYPHASE SQUIRREL-CAGE INDUCTION MOTORS	20-15
20.24.1	Effect on Performance—General.....	20-16
20.24.2	Voltage Unbalance Defined	20-16
20.24.3	Torques.....	20-16
20.24.4	Full-Load Speed	20-16
20.24.5	Currents	20-16
	MANUFACTURING	20-16
20.25	NAMEPLATE MARKING	20-16
20.25.1	Alternating-Current Polyphase Squirrel-Cage Motors	20-17
20.25.2	Polyphase Wound-Rotor Motors.....	20-17
20.25.3	Polyphase Squirrel-Cage Generators.....	20-17
20.25.4	Polyphase Wound-Rotor Generators	20-18
20.26	MOTOR TERMINAL HOUSINGS AND BOXES	20-18
20.26.1	Box Dimensions.....	20-18
20.26.2	Accessory Lead Terminations	20-18
20.26.3	Lead Terminations of Accessories Operating at 50 Volts or Less	20-18
20.27	EMBEDDED TEMPERATURE DETECTORS.....	20-19
	APPLICATION DATA.....	20-21
20.28	SERVICE CONDITIONS.....	20-21
20.28.1	General	20-21
20.28.2	Usual Service Conditions.....	20-21
20.28.3	Unusual Service Conditions.....	20-21
20.29	END PLAY AND ROTOR FLOAT FOR COUPLED SLEEVE BEARING HORIZONTAL INDUCTION MACHINES.....	20-22
20.29.1	General	20-22
20.29.2	Limits.....	20-22
20.29.3	Marking Requirements.....	20-22
20.30	PULSATING STATOR CURRENT IN INDUCTION MOTORS.....	20-23
20.31	ASEISMATIC CAPABILITY	20-23
20.31.1	General	20-23
20.31.2	Frequency Response Spectrum	20-23
20.31.3	Units for Capability Requirements	20-23
20.31.4	Recommended Peak Acceleration Limits.....	20-23
20.32	BELT, CHAIN, AND GEAR DRIVE.....	20-24

20.33	BUS TRANSFER OR RECLOSING	20-24
20.33.1	Slow Transfer or Reclosing.....	20-24
20.33.2	Fast Transfer or Reclosing	20-24
20.34	POWER FACTOR CORRECTION	20-25
20.35	SURGE CAPABILITIES OF AC WINDINGS WITH FORM- WOUND COILS	20-25
20.35.1	General	20-25
20.35.2	Surge Sources	20-25
20.35.3	Factors Influencing Magnitude and Rise Time	20-25
20.35.4	Surge Protection	20-26
20.35.5	Surge Withstand Capability for Standard Machines	20-26
20.35.6	Special Surge Withstand Capability	20-26
20.35.7	Testing	20-26
20.35.8	Test Voltage Values.....	20-26
20.36	MACHINES OPERATING ON AN UNGROUNDED SYSTEM	20-26
20.37	OCCASIONAL EXCESS CURRENT	20-27

Section III LARGE MACHINES

Part 21—LARGE MACHINES—SYNCHRONOUS MOTORS

RATINGS	21-1
21.1 SCOPE	21-1
21.2 BASIS OF RATING	21-1
21.3 HORSEPOWER AND SPEED RATINGS.....	21-2
21.4 POWER FACTOR.....	21-2
21.5 VOLTAGE RATINGS	21-2
21.5.1 Voltage Ratings.....	21-2
21.5.2 Preferred Motor Output/Voltage Rating	21-3
21.6 FREQUENCIES	21-3
21.7 EXCITATION VOLTAGE	21-3
21.8 SERVICE FACTOR	21-3
21.8.1 Service Factor of 1.0.....	21-3
21.8.2 Service Factor of 1.15.....	21-3
21.8.3 Application of Motor with 1.15 Service Factor	21-3
21.9 TYPICAL KW RATINGS OF EXCITERS FOR 60-HERTZ SYNCHRONOUS MOTORS.....	21-4
TESTS AND PERFORMANCE	21-9
21.10 TEMPERATURE RISE—SYNCHRONOUS MOTORS	21-9
21.10.1 Machines with 1.0 Service Factor at Rated Load	21-9
21.10.2 Machines with 1.15 Service Factor at Service Factor Load	21-9
21.10.3 Temperature Rise for Ambients Higher than 40°C	21-10
21.10.4 Temperature Rise for Altitudes Greater than 3300 Feet (1000 Meters).....	21-10
21.10.5 Temperature Rise for Air-Cooled Motors for Ambients Lower than 40°C, but Not Below 0°C.....	21-10
21.11 TORQUES	21-11
21.11.1 General	21-11
21.11.2 Motor Torques When Customer Supplies Load Curve.....	21-11
21.12 NORMAL WK ² OF LOAD.....	21-11
21.13 NUMBER OF STARTS	21-12
21.13.1 Starting Capability.....	21-12
21.13.2 Additional Starts.....	21-12
21.13.3 Information Plate.....	21-12
21.14 EFFICIENCY	21-12
21.15 OVERSPEED.....	21-13
21.16 OPERATION AT OTHER THAN RATED POWER FACTORS	21-13
21.16.1 Operation of an 0.8 Power-factor Motor at 1.0 Power-factor.....	21-13

21.16.2	Operation of a 1.0 Power-factor Motor at 0.8 Power-factor.....	21-14
21.17	VARIATIONS FROM RATED VOLTAGE AND RATED FREQUENCY	21-14
21.17.1	Running.....	21-14
21.17.2	Starting.....	21-14
21.18	OPERATION OF SYNCHRONOUS MOTORS FROM VARIABLE-FREQUENCY POWER SUPPLIES	21-14
21.19	SPECIFICATION FORM FOR SLIP-RING SYNCHRONOUS MOTORS	21-18
21.20	SPECIFICATION FORM FOR BRUSHLESS SYNCHRONOUS MOTORS.....	21-19
21.21	ROUTINE TESTS	21-20
21.21.1	Motors Not Completely Assembled in the Factory	21-20
21.21.2	Motors Completely Assembled in the Factory	21-20
21.22	HIGH-POTENTIAL TESTS	21-20
21.22.1	Safety Precautions and Test Procedure.....	21-20
21.22.2	Test Voltage—Armature Windings	21-20
21.22.3	Test Voltage—Field Windings, Motors with Slip Rings.....	21-20
21.22.4	Test Voltage—Assembled Brushless Motor Field Windings and Exciter Armature Winding	21-20
21.22.5	Test Voltage—Brushless Exciter Field Winding	21-21
21.23	MACHINE SOUND	21-21
21.24	MECHANICAL VIBRATION	21-21
	MANUFACTURING	21-21
21.25	NAMEPLATE MARKING	21-21
21.26	MOTOR TERMINAL HOUSINGS AND BOXES	21-22
21.26.1	Box Dimensions.....	21-22
21.26.2	Accessory Lead Terminations	21-22
21.26.3	Lead Terminations of Accessories Operating at 50 Volts or Less.....	21-22
21.27	EMBEDDED DETECTORS	21-24
	APPLICATION DATA	21-25
21.28	SERVICE CONDITIONS.....	21-25
21.28.1	General	21-25
21.28.2	Usual Service Conditions.....	21-25
21.28.3	Unusual Service Conditions.....	21-25
21.29	EFFECTS OF UNBALANCED VOLTAGES ON THE PERFORMANCE OF POLYPHASE SYNCHRONOUS MOTORS.....	21-26
21.29.1	Effect on Performance	21-27
21.29.2	Voltage Unbalanced Defined	21-27
21.30	COUPLING END PLAY AND ROTOR FLOAT FOR HORIZONTAL MOTORS	21-27
21.31	BELT, CHAIN, AND GEAR DRIVE.....	21-27
21.32	PULSATING ARMATURE CURRENT.....	21-27
21.33	TORQUE PULSATIONS DURING STARTING OF SYNCHRONOUS MOTORS	21-28
21.34	BUS TRANSFER OR RECLOSING	21-28
21.34.1	Slow Transfer of Reclosing.....	21-28
21.34.2	Fast Transfer of Reclosing.....	21-28
21.34.3	Bus Transfer Procedure.....	21-29
21.35	CALCULATION OF NATURAL FREQUENCY OF SYNCHRONOUS MACHINES DIRECT-CONNECTED TO RECIPROCATING MACHINERY	21-29
21.35.1	Undamped Natural Frequency.....	21-29
21.35.2	Synchronizing Torque Coefficient, P_r	21-29
21.35.3	Factors Influencing P_r	21-29
21.36	TYPICAL TORQUE REQUIREMENTS	21-29
21.37	COMPRESSOR FACTORS.....	21-34
21.38	SURGE CAPABILITIES OF AC WINDINGS WITH FORM-WOUND COILS	21-35

21.39	MACHINES OPERATING ON AN UNGROUNDED SYSTEM	21-35
21.40	OCCASIONAL EXCESS CURRENT	21-35

Section III LARGE MACHINES

Part 23—LARGE MACHINES—DC MOTORS LARGER THAN 1.25 HORSEPOWER PER RPM, OPEN TYPE

CLASSIFICATION	23-1
23.1 SCOPE	23-1
23.2 GENERAL INDUSTRIAL MOTORS	23-1
23.3 METAL ROLLING MILL MOTORS	23-1
23.3.1 Class N Metal Rolling Mill Motors	23-1
23.3.2 Class S Metal Rolling Mill Motors	23-1
23.4 REVERSING HOT MILL MOTORS	23-1
RATINGS	23-2
23.5 BASIS OF RATING	23-2
23.6 HORSEPOWER, SPEED, AND VOLTAGE RATINGS	23-3
23.6.1 General Industrial Motors and Metal Rolling Mill Motors, Classes N and S	23-3
23.6.2 Reversing Hot Mill Motors.....	23-4
23.7 SPEED RATINGS BY FIELD CONTROL FOR 250-VOLT DIRECT- CURRENT MOTORS.....	23-5
23.8 SPEED RATINGS BY FIELD CONTROL FOR 500- OR 700-VOLT DIRECT-CURRENT MOTORS	23-6
TESTS AND PERFORMANCE	23-8
23.9 TEMPERATURE RISE	23-8
23.9.1 Temperature Rise for Ambients Higher than 40°C	23-9
23.9.2 Temperature Rise for Altitudes Greater than 3300 Feet (1000 Meters).....	23-9
23.9.3 Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C.....	23-9
23.10 OVERLOAD CAPABILITY	23-10
23.10.1 General Industrial Motors	23-10
23.10.2 Metal Rolling Mill Motors (Excluding Reversing Hot Mill Motors)—Open, Forced-Ventilated, and Totally Enclosed Water- Air-Cooled	23-10
23.10.3 Reversing Hot Mill Motors—Forced-Ventilated and Totally Enclosed Water-Air-Cooled	23-11
23.11 MOMENTARY LOAD CAPACITY	23-11
23.12 SUCCESSFUL COMMUTATION	23-11
23.13 EFFICIENCY	23-11
23.14 TYPICAL REVERSAL TIME OF REVERSING HOT MILL MOTORS	23-12
23.15 IMPACT SPEED DROP OF A DIRECT-CURRENT MOTOR	23-12
23.16 OVERSPEED	23-12
23.17 VARIATION FROM RATED VOLTAGE.....	23-13
23.17.1 Steady State	23-13
23.17.2 Transient Voltages of Microsecond Duration.....	23-13
23.18 FIELD DATA FOR DIRECT-CURRENT MOTORS	23-13
23.19 ROUTINE TESTS	23-14
23.20 HIGH-POTENTIAL TEST	23-14
23.20.1 Safety Precautions and Test Procedure.....	23-14
23.20.2 Test Voltage	23-14
23.21 MECHANICAL VIBRATION	23-14
23.22 METHOD OF MEASURING THE MOTOR VIBRATION	23-14
23.23 CONDITIONS OF TEST FOR SPEED REGULATION.....	23-14
MANUFACTURING	23-14
23.24 NAMEPLATE MARKING	23-14

APPLICATION DATA	23-15
23.25 SERVICE CONDITIONS.....	23-15
23.25.1 General	23-15
23.25.2 Usual Service Conditions.....	23-15
23.25.3 Unusual Service Conditions.....	23-15
23.26 OPERATION OF DIRECT-CURRENT MOTORS ON RECTIFIED ALTERNATING CURRENT	23-16
23.26.1 General	23-16
23.26.2 Operation on Parallel with Power Supply with High Ripple	23-16
23.26.3 Bearing Currents.....	23-17
23.27 OPERATION OF DIRECT-CURRENT MOTORS BELOW BASE SPEED BY REDUCED ARMATURE VOLTAGE.....	23-17
23.28 RATE OF CHANGE OF LOAD CURRENT	23-17

Section III LARGE MACHINES

Part 24—LARGE MACHINES—DC GENERATORS LARGER THAN 1.0 KILOWATT PER RPM, OPEN TYPE CLASSIFICATION

24.0 SCOPE	24-1
24.1 GENERAL INDUSTRIAL GENERATORS.....	24-1
24.2 METAL ROLLING MILL GENERATORS.....	24-1
24.3 REVERSING HOT MILL GENERATORS.....	24-1
RATINGS	24-1
24.9 BASIS OF RATING.....	24-1
24.10 KILOWATT, SPEED, AND VOLTAGE RATINGS	24-2
TESTS AND PERFORMANCE	24-3
24.40 TEMPERATURE RISE	24-3
24.40.1 Temperature Rise for Ambients Higher than 40°C	24-4
24.40.2 Temperature Rise for Altitudes Greater than 3300 Feet (1000 Meters).....	24-4
24.40.3 Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C*	24-4
24.41 OVERLOAD CAPABILITY	24-5
24.41.1 General Industrial Generators	24-5
24.41.2 Metal Rolling Mill Generators (Excluding Reversing Hot Mill Generators)—Open, Forced-Ventilated, and Totally Enclosed Water-Air-Cooled	24-5
24.41.3 Reversing Hot Mill Generators—Forced-Ventilated and Totally Enclosed Water-Air-Cooled	24-5
24.42 MOMENTARY LOAD CAPACITY.....	24-5
24.43 SUCCESSFUL COMMUTATION	24-6
24.44 OUTPUT AT REDUCED VOLTAGE.....	24-6
24.45 EFFICIENCY.....	24-6
24.46 OVERSPEED.....	24-7
24.47 FIELD DATA FOR DIRECT-CURRENT GENERATORS.....	24-7
24.48 ROUTINE TESTS	24-7
24.49 HIGH POTENTIAL TESTS	24-7
24.49.1 Safety Precautions and Test Procedure.....	24-7
24.49.2 Test Voltage.....	24-8
24.50 CONDITIONS OF TESTS FOR VOLTAGE REGULATION	24-8
24.51 MECHANICAL VIBRATION	24-8
MANUFACTURING	24-8
24.61 NAMEPLATE MARKING	24-8
APPLICATION DATA	24-8
24.80 SERVICE CONDITIONS.....	24-8
24.80.1 General	24-8
24.80.2 Usual Service Conditions.....	24-9

	24.80.3 Unusual Service Conditions.....	24-9
24.81	RATE OF CHANGE OF LOAD CURRENT	24-9
24.82	SUCCESSFUL PARALLEL OPERATION OF GENERATORS.....	24-10
24.83	OPERATION OF DIRECT-CURRENT GENERATORS IN PARALLEL WITH RECTIFIED ALTERNATING-VOLTAGE POWER SUPPLY	24-10
	24.83.1 General	24-10
	24.83.2 Operation in Parallel with Power Supply with Ripple.....	24-10
	24.83.3 Bearing Currents.....	24-10
24.84	COMPOUNDING	24-11
	24.84.1 Flat Compounding	24-11
	24.84.2 Other	24-11

Section IV PERFORMANCE STANDARDS APPLYING TO ALL MACHINES

Part 30—APPLICATION CONSIDERATIONS FOR CONSTANT SPEED MOTORS USED ON A SINUSOIDAL BUS WITH HARMONIC CONTENT AND GENERAL PURPOSE MOTORS USED WITH ADJUSTABLE-VOLTAGE OR ADJUSTABLE-FREQUENCY CONTROLS OR BOTH

30.0	SCOPE	30-1
30.1	APPLICATION CONSIDERATIONS FOR CONSTANT SPEED MOTORS USED ON A SINUSOIDAL BUS WITH HARMONIC CONTENT	30-1
	30.1.1 Efficiency.....	30-1
	30.1.2 Derating for Harmonic Content.....	30-1
	30.1.3 Power Factor Correction.....	30-2
30.2	GENERAL PURPOSE MOTORS USED WITH ADJUSTABLE- VOLTAGE OR ADJUSTABLE-FREQUENCY CONTROLS OR BOTH.....	30-2
	30.2.1 Definitions	30-2
	30.2.2 Application Considerations	30-5

Section IV PERFORMANCE STANDARDS APPLYING TO ALL MACHINES

Part 31—DEFINITE-PURPOSE INVERTER-FED POLYPHASE MOTORS

31.0	SCOPE	31-1
31.1	SERVICE CONDITIONS.....	31-1
	31.1.1 General	31-1
	31.1.2 Usual Service Conditions.....	31-1
	31.1.3 Unusual Service Conditions.....	31-1
	31.1.4 Operation in Hazardous (Classified) Locations	31-2
31.2	DIMENSIONS, TOLERANCES, AND MOUNTING FOR FRAME DESIGNATIONS	31-2
31.3	RATING	31-3
	31.3.1 Basis of Rating.....	31-3
	31.3.2 Base Horsepower and Speed Ratings	31-3
	31.3.3 Speed Range	31-4
	31.3.4 Voltage.....	31-4
	31.3.5 Number of Phases	31-4
	31.3.6 Direction of Rotation	31-5
	31.3.7 Service Factor.....	31-5
	31.3.8 Duty.....	31-5
31.4	PERFORMANCE	31-5
	31.4.1 Temperature Rise	31-5
	31.4.2 Torque.....	31-9
	31.4.3 Operating Limitations.....	31-9
	31.4.4 Insulation Considerations	31-10
	31.4.5 Resonances, Sound, Vibration	31-12
	31.4.6 Bearing Lubrication at Low and High Speeds	31-12
31.5	NAMEPLATE MARKING	31-13
	31.5.1 Variable Torque Applications.....	31-13

	31.5.2 Other Applications	31-13
31.6	TESTS	31-13
	31.6.1 Test Method	31-13
	31.6.2 Routine Tests.....	31-14
	31.6.3 Performance Tests	31-14
31.7	ACCESSORY MOUNTING.....	31-14

Section IV PERFORMANCE STANDARDS APPLYING TO ALL MACHINES

Part 32—SYNCHRONOUS GENERATORS (EXCLUSIVE OF GENERATORS COVERED BY ANSI STANDARDS C50.12, C50.13, C50.14, AND C50.15 ABOVE 5000 kVA) RATINGS

32.0	SCOPE	32-1
32.1	BASIS OF RATING	32-1
32.2	KILOVOLT-AMPERE (KVA) AND (KW) RATINGS	32-1
32.3	SPEED RATINGS.....	32-1
32.4	VOLTAGE RATINGS.....	32-3
	32.4.1 Voltage Ratings for 60 Hz Circuits, Volts.....	32-3
	32.4.2 Voltage Ratings for 50 Hz Circuits, Volts.....	32-3
32.5	FREQUENCIES.....	32-3
32.6	TEMPERATURE RISE	32-3
	32.6.2 Temperature Rise for Air-Cooled Machines for Ambients Lower than 40° C, but Not Below 0° C.....	32-5
32.7	MAXIMUM MOMENTARY OVERLOADS.....	32-5
32.8	OVERLOAD CAPABILITY	32-6
32.9	OCCASIONAL EXCESS CURRENT	32-6
32.10	MAXIMUM DEVIATION FACTOR	32-6
32.11	TELEPHONE INFLUENCE FACTOR (TIF).....	32-6
32.12	EFFICIENCY.....	32-7
32.13	SHORT-CIRCUIT REQUIREMENTS	32-8
32.14	CONTINUOUS CURRENT UNBALANCE	32-8
32.15	OPERATION WITH NON-LINEAR OR ASYMMETRIC LOADS	32-9
32.16	OVERSPEEDS	32-9
32.17	VARIATION FROM RATED VOLTAGE.....	32-10
	32.17.1 Broad Voltage Range	32-10
	32.17.2 Discrete Voltage	32-10
32.18	SYNCHRONOUS GENERATOR VOLTAGE REGULATION (VOLTAGE DIP).....	32-10
	32.18.1 General	32-10
	32.18.2 Definitions	32-10
	32.18.3 Voltage Recorder Performance	32-12
	32.18.4 Examples	32-12
	32.18.5 Motor Starting Loads	32-12
32.19	PERFORMANCE SPECIFICATION FORMS	32-15
	32.19.1 Slip-ring Synchronous Generators	32-15
	32.19.2 Brushless Synchronous Generators	32-16
32.20	ROUTINE FACTORY TESTS.....	32-17
	32.20.1 Generators Not Completely Assembled in the Factory	32-17
	32.20.2 Generators Completely Assembled in the Factory	32-17
32.21	HIGH-POTENTIAL TESTS	32-17
	32.21.1 Safety Precautions and Test Procedures	32-17
	32.21.2 Test Voltage—Armature Windings	32-17
	32.21.3 Test Voltage—Field Windings, Generators with Slip Rings	32-17
	32.21.4 Test Voltage—Assembled Brushless Generator Field Winding and Exciter Armature Winding.....	32-17
	32.21.5 Test Voltage—Brushless Exciter Field Winding	32-18
32.22	MACHINE SOUND SYNCHRONOUS (GENERATORS).....	32-18

32.22.1	Sound Quality	32-18
32.22.2	Sound Measurement	32-18
32.23	VIBRATION.....	32-18
	MANUFACTURING DATA	32-19
32.24	NAMEPLATE MARKING	32-19
32.25	SHAFT EXTENSION KEY	32-19
32.26	GENERATOR TERMINAL HOUSING	32-19
32.27	EMBEDDED TEMPERATURE DETECTORS	32-20
	APPLICATION DATA	32-21
32.29	PARALLEL OPERATION	32-21
32.30	CALCULATION OF NATURAL FREQUENCY	32-21
32.31	TORSIONAL VIBRATION.....	32-21
32.32	MACHINES OPERATING ON AN UNGROUNDED SYSTEM	32-21
32.33	SERVICE CONDITIONS.....	32-21
	32.33.1 General	32-21
	32.33.2 Usual Service Conditions.....	32-22
	32.33.3 Unusual Service Conditions.....	32-22
32.34	NEUTRAL GROUNDING.....	32-23
32.35	STAND-BY GENERATOR	32-23
32.36	GROUNDING MEANS FOR FIELD WIRING	32-23

Section IV PERFORMANCE STANDARDS APPLYING TO ALL MACHINES

Part 33—DEFINITE PURPOSE SYNCHRONOUS GENERATORS FOR GENERATING SET APPLICATIONS

33.0	SCOPE	33-1
33.1	DEFINITIONS	33-1
	33.1.1 Rated Output Power	33-1
	33.1.2 Rated Speed of Rotation n	33-2
	33.1.3 Voltage Terms.....	33-2
	33.1.4 Performance Classes	33-4
33.2	RATINGS	33-5
	33.2.1 Power Factor.....	33-5
	33.2.2 Kilovolt – Ampere (kVA) and Kilowatt (kW) Ratings	33-5
	33.2.3 Speed.....	33-6
	33.2.4 Voltage.....	33-6
	33.2.5 Frequencies	33-7
33.3	PERFORMANCE	33-7
	33.3.1 Voltage and Frequency Variation	33-7
	33.3.2 Limits of Temperature and Temperature Rise	33-8
	33.3.3 Special Load Conditions	33-11
	33.3.4 Power Quality.....	33-12
	33.3.5 Overspeed	33-18
	33.3.6 Machine Sound.....	33-18
	33.3.7 Linear Vibration.....	33-19
	33.3.8 Testing	33-19
	33.3.9 Performance Specification Forms.....	33-22
33.4	APPLICATIONS.....	33-24
	33.4.1 Service Conditions.....	33-24
	33.4.2 Transient Voltage Performance	33-25
	33.4.3 Torsional Vibration	33-29
	33.4.4 Generator Grounding	33-29
	33.4.5 Cyclic Irregularity	33-30
	33.4.6 Application Criteria.....	33-30
33.5	MANUFACTURING	33-32
	33.5.1 Nameplate Marking.....	33-32
	33.5.2 Terminal Housings.....	33-33