



**ANSI C12.9-2014**  
Revision of ANSI C12.9-2005

*American National Standard for  
Test Switches and Plugs for Transformer-Rated Meters*

Secretariat:

**National Electrical Manufacturers Association**

Approved September 17, 2014

**American National Standards Institute**

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

ANSI standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

# AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**CAUTION NOTICE:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association  
1300 North 17th Street, Suite 900, Rosslyn, Virginia 22209**

© 2014 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

**Foreword** (This foreword is not part of American National Standard C12.9-2014.)

This standard is a major revision of ANSI C12.9-2005, *American National Standard for Test Switches for Transformer-Rated Meters*. It was developed by the Accredited Standards Committee on Electricity Metering, C12, for full consensus approval as an American National Standard. This revised version supersedes ANSI C12.9-2005.

This standard covers the dimensions and functions of meter test switches for transformer-rated watt-hour meters when used in conjunction with instrument transformers. It also adds specifications for test jacks used in conjunction with the test switches. These additions ensure that test jacks used in conjunction with switches meeting this standard will operate properly and safely.

Suggestions for improvements of this standard are welcome. They should be in the form of a proposed change of text, together with appropriate supporting comments.

Comments on standards and requests for interpretations should be addressed to:

**ANSI Committee C12 Secretary**  
**National Electrical Manufacturers Association**  
**1300 North 17<sup>th</sup> Street**  
**Rosslyn, Virginia 22209**

At the time this standard was completed, the American National Standards Committee C12 had the following membership:

**Tom Nelson, Chairman**  
**Paul Orr, Secretary**

<i>Organization Represented:</i>	<i>Name of Representative</i>
Ameren Services	J. West
Austin Energy	H. Millican
Baltimore Gas & Electric Company	J. Thurber
Center for Neighborhood Technology	L. Kotewa
Consumers Energy	D. Jirikovic
DTE Energy	K. Tolios
Duke Power Company	T. Morgan
Elster Solutions	S. Weikel
EnerNex Corporation	A. Snyder
Florida Power & Light	J. DeMars
Future DOS R&D Inc.	A. Moise
GE Energy	C. Crittenden
Georgia Power	L. Barto
Itron, Inc.	B. Cain
JECARRCO, LLC	J. Carr
Landis+Gyr	J. Voisine
MET Laboratories, Inc.	J. Reed
Milbank Manufacturing Company	S. Glasgow
National Institute of Standards and Technology	T. Nelson
Oncor Group	B. Johnson
Pacific Gas & Electric	D. Y. Nguyen
Power Measurements	B. Hardy
Public Service Electric & Gas	D. Ellis
Radian Research	S. Edwards

SAIC  
 Schweitzer Engineering Labs  
 Sensus Metering  
 Silver Spring Networks  
 Technology for Energy Corp.  
 TESCO  
 Trilliant Networks  
 Tucker Engineering  
 Underwriters Laboratories Inc.  
 Watthour Engineering Company  
 Xcel Energy

D. Scott  
 T. Mooney  
 K. O'Dell  
 K. Oza  
 S. Hudson  
 T. Lawton  
 M. Veillette  
 R. Tucker  
 S. Hunter  
 L. Wren  
 D. Nordell

At the time this standard was completed, Subcommittee 15 of ANSI Committee C12, which developed and revised this standard, had the following membership:

**Shawn Glasgow, Chairman**  
**Paul Orr, Secretary**

*Organization Represented:*

*Name of Representative:*

Center for Neighborhood Technology  
 DTE Energy  
 Duke Energy  
 Elster Solutions  
 EnerNex Corporation  
 Florida Power & Light  
 GE Energy  
 Georgia Power  
 ITI  
 Landis+Gyr  
 Milbank Manufacturing  
 NIST  
 Oncor  
 Pacific Gas & Electric  
 Power Measurements  
 Public Service Electric & Gas  
 Siemens Industry, Inc.  
 Technology For Energy Corp  
 The Durham Company

L. Kotewa  
 K. Tolios  
 R. Wesley  
 S. Weikel  
 A. Snyder  
 J. DeMars  
 C. Crittenden  
 L. Barto  
 B. Sonnenberg  
 J. Voisine  
 S. Glasgow  
 T. Nelson  
 B. Johnson  
 D. Y. Nguyen  
 B. Hardy  
 D. Ellis  
 W. Rose  
 S. Hudson  
 M. Shoemaker

## Contents

Foreword.....	ii
<b>1 Scope .....</b>	<b>1</b>
<b>2 Definitions .....</b>	<b>1</b>
2.1 short-circuiting switch.....	1
2.2 test jack.....	1
2.3 test-jack switch.....	1
2.4 test plug.....	1
2.5 voltage switch.....	1
<b>3 Standard Ratings .....</b>	<b>1</b>
3.1 Current.....	1
3.2 Voltage.....	1
<b>4 General Requirements for Test Switches.....</b>	<b>1</b>
4.1 Material and workmanship.....	1
4.2 Nameplates.....	1
4.3 Movable parts .....	1
4.4 Number of poles .....	2
4.5 Alternate switch arrangements .....	5
4.6 Provision for test plugs .....	5
4.7 Insulating barriers .....	7
4.8 Wiring terminals and test clips.....	7
4.8.1 Wiring terminals.....	7
4.8.2 Test clips .....	7
4.9 Mounting holes.....	7
4.10 Cover.....	7
4.10.1 General.....	7
4.10.2 Cover holes .....	7
4.10.3 Cover studs .....	7
4.11 Acceptable spacing.....	8
<b>5 Test Switch Performance.....</b>	<b>8</b>
<b>6 General requirements for test plugs.....</b>	<b>9</b>
6.1 Materials and workmanship.....	9
 <b>Tables</b>	
Table 1 Test Switch Dimensions.....	7
Table 2 Minimum Acceptable Spacing.....	8

Table 3 Test Plug Dimensions .....	10
------------------------------------	----

## Figures

Figure 1 Alternative Arrangements and Dimensions for Four-Pole Switches .....	2
Figure 2 Alternative Arrangements and Dimensions for Seven-Pole, Seven-Position Switches .....	3
Figure 3 Alternative Arrangements and Dimensions for Seven-Pole, Ten-Position Switches .....	4
Figure 4 Alternative Arrangements and Dimensions for Ten-Pole Switches .....	5
Figure 5 Test Switch Typical Cross Section.....	6
Figure 6 Performance Test Wiring Diagram .....	9
Figure 7 Typical Test Plug.....	10

**< This page intentionally left blank. >**



## 1 Scope

This standard is intended to encompass the dimensions and functions of meter test switches used with transformer-rated watt-hour meters in conjunction with instrument transformers and test plugs used in conjunction with the test switch.

## 2 Definitions

- 2.1 **short-circuiting switch:** A single-pole double-throw (make-before-break) transfer switch used to transfer current away from the meter.
- 2.2 **test jack:** A spring-jaw receptacle in the current element of a test switch that provides a bipolar test connection in the metering current circuit without interruption of the current circuit.
- 2.3 **test-jack switch:** A single-pole, single-throw disconnect switch used in conjunction with a test jack to provide a parallel current path during normal operating conditions.
- 2.4 **test plug:** A bipolar mating plug to a test jack for inserting instrumentation into the metering-current circuit.
- 2.5 **voltage switch:** A single-pole, single-throw switch used to open or close a voltage circuit.

## 3 Standard Ratings

### 3.1 Current

The current rating shall be 20 A minimum.

### 3.2 Voltage

The voltage rating shall be 300 V or 600 V.

## 4 General Requirements for Test Switches

### 4.1 Material and workmanship

The test switch and its components shall be substantially constructed of suitable material in a workmanlike manner.

### 4.2 Nameplates

Nameplates are not required on these test switches, but a manufacturer's identifying marking (such as catalog number, trademark, etc.) shall be stamped, printed, affixed, or cast in a convenient place on each test switch. When required, a warning label indicating hidden internal jumpers should be affixed.

### 4.3 Movable parts

Movable conducting parts, such as blade hinges, shall be held in place by locknuts or pins or their equivalent, arranged so that a firm and secure connection will be maintained at any position of the switch blade.