



Approved as an American National Standard
ANSI Approval Date: September 23, 2020

Identical National Adoption of IEC 60529:
1989/AMD2:2013/COR1:2019

ANSI/IEC 60529-2020

Degrees of Protection Provided by Enclosures (IP Code)
(Identical National Adoption)

Published by

National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

© 2020 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions. These materials are subject to copyright claims of IEC, ANSI, and NEMA. Not for resale. No part of this publication may be reproduced in any form, including an electronic retrieval system, without the prior written permission of NEMA. All requests pertaining to the ANSI/NEMA Standard should be submitted to NEMA.

Notice and Disclaimer (ANSI Adoption of IEC Standards)

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. NEMA does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the Standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the Standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the Standards.

The American National Standards Institute does not develop Standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this Standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this Standard. Purchasers of American National Standards may receive current information on all Standards by calling or writing the American National Standards Institute, 25 West 43rd Street, 4th floor, New York, NY 10036, Tel: 212.642.4900.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209**

www.nema.org

© 2020 National Electrical Manufacturers Association. All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

< This page intentionally left blank. >

Foreword for U.S. Adoption

This American National Standard is an adoption of IEC 60529, Edition 2.0, *Degrees of protection provided by enclosures (IP Code)* and was developed and approved in accordance with procedures set forth by the American National Standards Institute. This Standard contains all the original text from IEC 60529, Edition 2.0.

Suggestions for the improvement of this Standard are welcome and should be submitted to the Secretariat of Accredited Standards Committee W1 as follows:

NEMA Technical Operations Department
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

This Standard was processed and approved by a Canvass Committee. Committee approval does not necessarily imply that all Committee Members voted for its approval.

CONTENTS

| | |
|---|----|
| FOREWORD | 5 |
| INTRODUCTION | 7 |
| INTRODUCTION TO AMENDMENT 2 | 8 |
| | |
| 1 Scope and object | 9 |
| 2 Normative references | 10 |
| 3 Definitions | 10 |
| 4 Designations | 12 |
| 4.1 Arrangement of the IP Code | 12 |
| 4.2 Elements of the IP Code and their meanings | 12 |
| 4.3 Examples for the use of letters in the IP Code | 13 |
| 5 Degrees of protection against access to hazardous parts and against solid foreign objects indicated by the first characteristic numeral | 14 |
| 5.1 Protection against access to hazardous parts | 14 |
| 5.2 Protection against solid foreign objects | 15 |
| 6 Degrees of protection against ingress of water indicated by the second characteristic numeral | 16 |
| 7 Degrees of protection against access to hazardous parts indicated by the additional letter | 18 |
| 8 Supplementary letters | 19 |
| 9 Examples of designations with the IP Code | 20 |
| 9.1 IP Code not using optional letters: | 20 |
| 9.2 IP Code using optional letters: | 20 |
| 10 Marking | 21 |
| 11 General requirements for tests | 21 |
| 11.1 Atmospheric conditions for water or dust tests | 21 |
| 11.2 Test samples | 21 |
| 11.3 Application of test requirements and interpretation of test results | 22 |
| 11.4 Combination of test conditions for the first characteristic numeral | 22 |
| 11.5 Empty enclosures | 22 |
| 12 Tests for protection against access to hazardous parts indicated by the first characteristic numeral | 23 |
| 12.1 Access probes | 23 |
| 12.2 Test conditions | 23 |
| 12.3 Acceptance conditions | 24 |
| 12.3.1 For low-voltage equipment (rated voltages not exceeding 1 000 V a.c. and 1 500 V d.c.) | 24 |
| 12.3.2 For high-voltage equipment (rated voltages exceeding 1 000 V a.c. and 1 500 V d.c.) | 25 |
| 12.3.3 For equipment with hazardous mechanical parts | 25 |
| 13 Tests for protection against solid foreign objects indicated by the first characteristic numeral | 25 |
| 13.1 Test means | 25 |

| | | |
|---|--|----|
| 13.2 | Test conditions for first characteristic numerals 1, 2, 3, 4 | 26 |
| 13.3 | Acceptance conditions for first characteristic numerals 1, 2, 3, 4 | 26 |
| 13.4 | Dust test for first characteristic numerals 5 and 6 | 26 |
| 13.5 | Special conditions for first characteristic numeral 5 | 27 |
| 13.5.1 | Test conditions for first characteristic numeral 5 | 27 |
| 13.5.2 | Acceptance conditions for first characteristic numeral 5 | 27 |
| 13.6 | Special conditions for first characteristic numeral 6 | 27 |
| 13.6.1 | Test conditions for first characteristic numeral 6 | 27 |
| 13.6.2 | Acceptance conditions for first characteristic numeral 6 | 27 |
| 14 | Tests for protection against water indicated by the second characteristic numeral | 27 |
| 14.1 | Test means | 27 |
| 14.2 | Test conditions | 28 |
| 14.2.1 | Test for second characteristic numeral 1 with the drip box | 29 |
| 14.2.2 | Test for second characteristic numeral 2 with the drip box | 29 |
| 14.2.3 | Test for second characteristic numeral 3 with oscillating tube or spray nozzle | 30 |
| 14.2.4 | Test for second characteristic numeral 4 with oscillating tube or spray nozzle | 30 |
| 14.2.5 | Test for second characteristic numeral 5 with the 6,3 mm nozzle | 31 |
| 14.2.6 | Test for second characteristic numeral 6 with the 12,5 mm nozzle | 31 |
| 14.2.7 | Test for second characteristic numeral 7: temporary immersion between 0,15 m and 1 m | 32 |
| 14.2.8 | Test for second characteristic numeral 8: continuous immersion subject to agreement | 32 |
| 14.2.9 | Test for second characteristic numeral 9 with a spray nozzle | 32 |
| 14.3 | Acceptance conditions | 33 |
| 15 | Tests for protection against access to hazardous parts indicated by the additional letter | 33 |
| 15.1 | Access probes | 33 |
| 15.2 | Test conditions | 33 |
| 15.3 | Acceptance conditions | 33 |
| Annex A (informative) | Examples of IP coding for the verification of protection of low-voltage equipment against access to hazardous parts | 44 |
| Annex B (informative) | Summary of responsibilities of relevant technical committees | 50 |
| Bibliography | 51 | |
| Figure 1 – Jointed test finger | 35 | |
| Figure 2 – Test device to verify protection against dust (dust chamber) | 36 | |
| Figure 3 – Test device to verify protection against vertically falling water drops (drip box) | 37 | |
| Figure 4 – Test device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (oscillating tube) | 38 | |
| Figure 5 – Hand-held device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (spray nozzle) | 39 | |

| | |
|---|----|
| Figure 6 – Test device to verify protection against water jets (hose nozzle) | 39 |
| Figure 7 – Fan jet nozzle dimensions | 39 |
| Figure 8 – Fan jet nozzle resulting dimensions of spraying hole for checking purpose | 39 |
| Figure 9 – Fan jet nozzle examples..... | 40 |
| Figure 10 – Set-up for measuring the impact force of the water jet for determining the protection against high-pressure and temperature water jet, degree of protection against ingress of water IP X9..... | 41 |
| Figure 11 – Impact force distribution | 41 |
| Figure 12 – Test device to verify protection against high pressure and temperature water jet for small enclosures | 42 |
| | |
| Table 1 – Degrees of protection against access to hazardous parts indicated by the first characteristic numeral..... | 15 |
| Table 2 – Degrees of protection against solid foreign objects indicated by the first characteristic numeral..... | 16 |
| Table 3 – Degrees of protection against water indicated by the second characteristic numeral..... | 18 |
| Table 4 – Degrees of protection against access to hazardous parts indicated by the additional letter | 19 |
| Table 5 – Test conditions for degrees of protection indicated by the first characteristic numeral..... | 22 |
| Table 6 – Access probes for the tests for protection of persons against access to hazardous parts | 23 |
| Table 7 – Test means for the tests for protection against solid foreign objects | 25 |
| Table 8 – Test means and main test conditions for the tests for protection against water | 28 |
| Table 9 – Total water flow rate q_V under IPX3 and IPX4 test conditions – Mean flow rate per hole $q_{Vl} = 0,07 \text{ l/min}$ | 31 |
| | |
| IP Codes of examples in Annex A | 49 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**DEGREES OF PROTECTION PROVIDED
BY ENCLOSURES (IP Code)****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS), and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end-user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and Members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This Consolidated version of IEC 60529 bears the edition number 2.0.

It consists of the second edition (1989) [documents 70(CO)13 + 70(CO)15 and 70(CO)16 + 70(CO)17], its amendment 1 (1999) [documents 70/91/FDIS and 70/92/RVD], its corrigendum 1 (2003), its corrigendum 2 (2007), its corrigendum 3 (2009), its amendment 2 [documents 70/122/FDIS and 70/123/RVD] its corrigendum 1 (2013), its corrigendum 2 (2015) and its corrigendum 1 (2019). The technical content is identical to the base edition and its amendments.

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available.

This publication has been prepared for user convenience.

International Standard IEC 60529 has been prepared by technical committee 70: Degrees of protection by enclosures.

Annexes A and B are for information only.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed
- withdrawn
- replaced by a revised edition
- amended

The contents of the corrigenda of October 2013, May 2015, and January 2019 have been included in this copy.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colors that are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

This Standard describes a system for classifying the degrees of protection provided by the enclosures of electrical equipment. While this system is suitable for use with most types of electrical equipment, it should not be assumed that all the listed degrees of protection are applicable to a particular type of equipment. The manufacturer of the equipment should be consulted to determine the degrees of protection available and the parts of equipment to which the stated degree of protection applies.

The adoption of this classification system, wherever possible, will promote uniformity in methods of describing the protection provided by the enclosure and in the tests to prove the various degrees of protection. It should also reduce the number of types of test devices necessary to test a wide range of products.

This second edition of IEC 60529 takes account of experiences with the first edition, and clarifies the requirements. It provides for an optional extension of the IP Code by an additional letter A, B, C, or D if the actual protection of persons against access to hazardous parts is higher than that indicated by the first characteristic numeral.

In general, enclosures with an IP coding to the first edition would be eligible for the same code according to this edition.

INTRODUCTION TO AMENDMENT 2

This Amendment 2 introduces a new degree of protection IP X9 whereas no modifications of the existing degrees of protection are made.

Thus neither additional tests nor modifications of the existing certificates should be requested in case of enclosures providing a different IP code.

DEGREES OF PROTECTION PROVIDED BY ENCLOSURES (IP Code)

1 Scope and object

This Standard applies to the classification of degrees of protection provided by enclosures for electrical equipment with a rated voltage not exceeding 72,5 kV.

The object of this Standard is to give:

- a) *Definitions* for degrees of protection provided by enclosures of electrical equipment as regards:
 - 1) protection of persons against access to hazardous parts inside the enclosure;
 - 2) protection of the equipment inside the enclosure against ingress of solid foreign objects;
 - 3) protection of the equipment inside the enclosure against harmful effects due to the ingress of water.
- b) *Designations* for these degrees of protection.
- c) *Requirements* for each designation.
- d) *Tests* to be performed to verify that the enclosure meets the requirements of this Standard.

It will remain the responsibility of individual technical committees to decide on the extent and manner in which the classification is used in their Standards and to define "enclosure" as it applies to their equipment. However, it is recommended that for a given classification the tests do not differ from those specified in this Standard. If necessary, complementary requirements may be included in the relevant product Standard. A guide for the details to be specified in relevant product Standards is given in annex B.

For a particular type of equipment, a technical committee may specify different requirements provided that at least the same level of safety is ensured.

This Standard deals only with enclosures that are in all other respects suitable for their intended use as specified in the relevant product Standard and which from the point of view of materials and workmanship ensure that the claimed degrees of protection are maintained under the normal conditions of use.

This Standard is also applicable to empty enclosures provided that the general test requirements are met and that the selected degree of protection is suitable for the type of equipment to be protected.

Measures to protect both the enclosure and the equipment inside the enclosure against external influences or conditions such as:

- mechanical impacts
- corrosion
- corrosive solvents (for example, cutting liquids)
- fungus
- vermin
- solar radiation
- icing
- moisture (for example, produced by condensation)
- explosive atmospheres

The protection against contact with hazardous moving parts external to the enclosure (such as fans) matters for the relevant product Standard to be protected.

Barriers external to the enclosure and not attached to it and obstacles which have been provided solely for the safety of personnel are not considered as a part of the enclosure and are not dealt with in this Standard.