

Approved as an American National Standard
ANSI Approval Date: February 7, 2020



ANSI/NEMA WC 53/ICEA T-27-581-2020
*Standard Test Methods for Extruded Dielectric Power, Control, Instrumentation,
and Portable Cables for Test*

Prepared by:

Insulated Cable Engineers Association, Inc.

www.icea.net

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

©2020 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

Approved June 4, 2018, by
Insulated Cable Engineers Association, Inc.

©2020 Insulated Cable Engineers Association, Inc. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the international and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

ANSI Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process to promote fairness in the development of consensus, it does not write the document, and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

Foreword	iv
Section 1 General	1
1.1 Scope	1
1.2 References.....	1
1.2.1 Normative References	1
Section 2 Electrical Methods.....	4
2.1 Conductor DC Resistance.....	4
2.1.1 Method When Sample Nominal Resistance is 1 Ohm or More	4
2.1.2 Method When Sample Nominal Resistance is Less Than 1 Ohm	4
2.1.3 Precautions for Short Sample Method	4
2.1.4 Converting Measured Conductor Resistance to Resistance at 25°C	5
2.2 Voltage Tests on Completed Cables	5
2.2.1 General	5
2.2.2 AC Voltage Test.....	6
2.2.3 DC Voltage Test.....	6
2.2.4 Spark Testing	6
2.3 Insulation Resistance	8
2.3.1 Single Conductor Cables	8
2.3.2 Multiple Conductor Cables	8
2.3.3 Method to Determine the 1°F Coefficient Factor for an Insulation.....	8
2.3.4 Converting Insulation Resistance to Insulation Resistance Constant	9
2.4 Dissipation Factor (DF), Capacitance (C), and Dielectric Constant	11
2.5 Suitability of Insulation Compounds for Use on DC Circuits in Wet Locations	11
2.6 Accelerated Water Absorption Test (EM-60)	12
2.7 Dielectric Constant and Voltage Withstand for Nonconducting Stress Control Layers	12
2.8 Specific Surface Resistivity	13
2.9 U-Bend Discharge Resistance	13
2.10 Track Resistance	13
2.11 Volume Resistivity.....	14
2.11.1 Conductor Stress Control.....	14
2.11.2 Insulation Shield.....	15
2.11.3 Four-Electrode Method	15
2.12 Semiconducting Jacket Radial Resistivity Test	15
2.12.1 Sample Preparation	15
2.12.2 Test Equipment Setup	17
2.12.3 Calculation	17
2.13 Dry Electrical Test for Class Iii Insulations (Shielded Medium Voltage Only).....	18
2.13.1 Test Samples	18
2.13.2 Test Procedure.....	18
2.13.3 Electrical Measurements.....	18
2.14 Discharge Resistance Test for Discharge Resistant Insulation	18
2.14.1 Test Specimens	18
2.14.2 Test Environment.....	18
2.14.3 Test Electrodes	18
2.15 Wet Insulation Resistance Stability (600 – 2000 Volts)	19
Section 3 Dimensional Methods	20
3.1 Conductor Cross-Sectional Area by Diameter Measurements	20
3.2 Thickness of Components over a Conductor.....	20
3.2.1 Optical Measuring Device Method for Any Component.....	20
3.2.2 Micrometer Method for Un-Bonded Components	20
3.2.3 Extruded Polymeric Components	20

3.2.4	Tape	20
3.2.5	Sheath	21
3.2.6	Bedding and Servings	21
3.3	Diameter Over Cable Components	21
3.3.1	Measurement Method for Conductors	21
3.3.2	Method for Any Component except Conductors	21
3.3.3	Tape Method for Any Component Having a Diameter 0.750 inch (19.1 mm) or Greater	21
3.4	Protrusion and Convolution Measurement	21
	Section 4 Physical Methods	23
4.1	Adhesion (Stripping Force)	23
4.2	Cold Bend	23
4.3	Heat Deformation (Distortion)	23
4.3.1	Insulation or Covering Deformation	23
4.3.2	Deformation of Jackets, Non-Conducting and Semiconducting	25
4.4	Flexibility Test for Interlocked Armor	25
4.5	Tear Resistance	25
4.6	Gravimetric Water Absorption	26
4.7	Direction and Length Of Lay	27
4.8	Jacket Irregularity Inspection	27
4.9	Hot Creep Test	28
4.10	Flame Tests	28
4.10.1	Vertical Tray Flame Test (Cable)	28
4.10.2	Vertical Flame Test (Single-Wire)	29
4.11	Physical and Aging Tests for Coverings, Insulations, Jackets, and Nonmetallic Conducting Materials	30
4.11.1	Sampling	30
4.11.2	Number of Test Specimens	30
4.11.3	Size and Preparation of Specimens	30
4.11.4	Calculation for Area of Test Specimens	31
4.11.5	Physical Test Procedures	31
4.11.6	Retests	31
4.11.7	Tensile Strength Test	32
4.11.8	Tensile Stress Test	32
4.11.9	Elongation Test	32
4.11.10	Set Test	33
4.11.11	Aging Tests	33
4.11.12	Physical Tests for Semiconducting Materials Intended for Extrusion	34
4.12	Absorption Coefficient	34
4.13	Heat Shock	34
4.14	Environmental Cracking	35
4.14.1	Test Specimens	35
4.14.2	Test Procedures	35
4.15	Method for Flexibility Test for Continuous Corrugated Armor	35
4.16	Shrinkback Test	35
4.16.1	Sample Preparation	35
4.16.2	Test Procedure	36
4.17	Wafer Boil Test for Conductor and Insulation Shields	36
4.18	Extruded Insulation Shield Removability (Field Strippability) Test	36
4.19	Tightness of Polyethylene Jacket to Sheath Test	36

List of Tables

Table 1-1	Kcmil Equivalent of Awg Conductor Sizes	3
Table 1-2	Conversion Table	3
Table 2-1	Factors for Converting Measured DC Resistance of Conductors To 5°C	5
Table 2-2	Temperature Correction Factors (Tcf) for Converting Insulation Resistance to 5.6°C.....	10
Table 2-3	Insulation Resistance Stabilization Period	19
Table 4-1	Load vs. Conductor Size in Heat Deformation Test	25
Table 4-2	Jacket Irregularity Inspection.....	29
Table 4-3	Jaw Speed Rate for Tensile Strength Test.....	33
Table 4-4	Mandrel Size for Heat Shock Test.....	36

Foreword

This Standard Test Methods Publication for Extruded Dielectric Power, Control, Instrumentation, and Portable Cables was developed by the Insulated Cable Engineers Association, Inc. (ICEA) and was approved by the National Electrical Manufacturers Association (NEMA).

ICEA/NEMA Standards are adopted in the public interest and are designed to eliminate misunderstandings between the manufacturers and the user and to assist the user in selecting and obtaining the proper product for his or her particular need. The user of this Standards Publication is cautioned to observe any health or safety regulations and rules relative to the use of the test procedures covered by this document.

Requests for interpretation of this Standard must be submitted in writing to:

Insulated Cable Engineers Association, Inc.
www.icea.net

An official written interpretation will be made by the Association.

Suggestions for improvements gained in the use of this publication will be welcomed by the Association.

Section 1 General

1.1 Scope

This Standard applies to the testing of covered conductors, extruded dielectric insulated power, control, instrumentation, and portable cables.