



Approved as an American National Standard
ANSI Approval Date: September 18, 2014

**ANSI/NEMA WC 51
ICEA P-54-440-2009 (R2014)**

Ampacities of Cables Installed in Cable Trays

Prepared by:

Insulated Cable Engineers Association, Inc.
P.O. Box 1568
Carrollton, Georgia 30112

Published by:

National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

© 2016 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) and the Insulated Cable Engineers Association, Inc. (ICEA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together persons who have an interest in the topic covered by this publication. While NEMA and ICEA administer the process and establish rules to promote fairness in the development of consensus, they do not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in their standards and guideline publications.

NEMA and ICEA disclaim liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA and ICEA disclaim and make no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaim and make no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA and ICEA do not undertake to guarantee the performance of any individual manufacturer's or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA and ICEA are not undertaking to render professional or other services for or on behalf of any person or entity, nor are NEMA and ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA and ICEA have no power, nor do they undertake to police or enforce compliance with the contents of this document. NEMA and ICEA do not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and ICEA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This standards publication for *Ampacities of Cables Installed in Cable Trays* (ICEA P-54-440, NEMA WC 51-2014) was developed by the Insulated Cable Engineers Association, Inc. (ICEA) and approved by the National Electrical Manufacturers Association (NEMA). It supersedes WC 51-2009.

ICEA/NEMA standards are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and the user and to assist the user in selecting and obtaining the proper product for his particular need. Existence of an ICEA/NEMA standard does not in any respect preclude the manufacture or use of products not conforming to the standard. The user of this standard is cautioned to observe any health or safety regulations and rules relative to the manufacture and use of cable made in conformity with this Standard.

Requests for interpretation of this Standard must be submitted in writing to:

Insulated Cable Engineers Association, Inc.,
P.O. Box 1568,
Carrollton, Georgia 30112
www.icea.net

An official written interpretation will be provided. ICEA will welcome any suggestions on ways to improve this standard.

<This page intentionally left blank.>

CONTENTS

	Page
Foreword	i
Scope	iv
History	iv
Section 1 GENERAL INFORMATION	1
1.1 Background	1
1.2 References	1
1.2.1 Normative References.....	1
1.2.2 Other References	2
1.3 DEFINITIONS.....	2
Section 2 TABLE DEVELOPMENT PARAMETERS	4
2.1 Parameters Used to Develop Tray Ampacity Tables	4
2.1.1 Cable Operating Temperatures.....	4
2.1.2 Allowable Heat Generation.....	4
2.1.3 Calculated Depth of Cables in Trays – Apparent Fill Depth.....	5
2.1.4 Cable Diameters.....	5
2.1.5 Conductor Resistance	5
2.1.6 Calculated Free-Air Ampacity.....	5
2.1.7 Ampacity Values.....	6
Section 3 AMPACITY ADJUSTMENT FACTORS	7
3.1 Correction Factor for Diameters of Cables.....	7
3.2 Correction Factor for Temperatures	7
3.2.1 Ambient Temperature.....	7
3.2.2 Conductor Temperature	8
3.3 Correction Factor for Number of Conductors	8
3.4 Correction Factors for Tray Covers	9
3.5 Correction Factors for Load Diversity.....	9
3.5.1 Determining the Loading Factor	9
3.5.2 Diversity Factors.....	10
Section 4 EXAMPLES	11
4.1 Calculating Apparent Depth of Cable	11
4.2 Selecting Ampacity Values and Using Adjustment Factors	12
4.3 Calculating and Applying Diversity Factors.....	13
4.4 Multiple Adjustment Factors	13
4.5 Calculating Ampacities for Cables Not Covered by Tables.....	14
Section 5 TABLES.....	15
5.1 Index to Tables	15

Scope

This Standards Publication covers the ampacity ratings for 600-15,000 volt solid dielectric cables installed in cable trays. Ampacity ratings are tabulated for single conductor cables, triplexed assemblies of single conductor cables, and three-conductor cables incorporating an overall jacket.

Ampacities have been tabulated for the cable constructions and the operating conditions normally encountered for tray applications. Correction factors to adjust the tabulated values to better reflect specific conditions are provided. These include adjustments to account for ambient and operating temperatures, cable construction, tray covers, and diversification of the cable loading.

This standard is intended primarily for use by the utility industry. It is not intended for use where compliance with the *National Electrical Code*[®] or other regulations is mandatory.