



Approved as an American National Standard
ANSI Approval Date: October 29, 2014

NEMA Standards Publication FB 1-2014

*Fittings, Cast Metal Boxes, and Conduit Bodies
for Conduit, Electrical Metallic Tubing, and Cable*

Published by

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900

Rosslyn, VA 22209

www.nema.org

© 2014 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This Standards Publication provides practical information concerning construction, test, performance, and manufacture of fittings, cast metal boxes, and conduit bodies for conduit, tubing, and cable assemblies. It is intended for use by the electrical industry to provide guidelines for the manufacture and proper application of these products, and to promote the benefits of repetitive manufacture and widespread product availability.

One of the primary purposes of this Standards Publication is to encourage the manufacture and utilization of products that function in accordance with this standard. While some sections of this publication are intended to eliminate misunderstandings between manufacturers and users, all sections, when applied properly, contribute to safety in one way or another.

The proper manufacture of fittings, cast metal boxes, and conduit bodies is, however, only one consideration in promoting the safe use of electricity. Other safety considerations involve the joint efforts of the system designer, the various equipment manufacturers, the installer, and the user. Information is provided in this standard, and in NEMA Standards Publications FB 2.10 and FB 2.20, to assist in proper selection and use.

The following factors are vital in a safe electrical system and should be considered by the user in the selection and application of equipment covered by the publication:

- a) Environmental conditions
- b) System design
- c) Equipment selection and application
- d) Installation
- e) Operating practices
- f) Maintenance

This Standards Publication has been published with a view to promoting the safety of persons and property when products conforming to it are selected, installed, and maintained in accordance with the *National Electrical Code*[®] (*NEC*).

NEMA Standards Publications are periodically reviewed to meet changing conditions and technical progress, and the latest edition shall be utilized. Comments from the users of this Standards Publication are welcome and should be sent to:

Senior Technical Director, Operations
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, VA 22209

At the time of publication, the Conduit Fittings Section of NEMA had the following members:

Adalet, a Division of Scott Fetzer	Cleveland, OH
AFC Cable Systems, Part of Atkore International	New Bedford, MA
Appleton Group	Rosemont, IL
Arlington Industries, Inc.	Scranton, PA
Bridgeport Fittings, Inc.	Bridgeport, CT
Calpipe Industries, Inc.	Rancho Dominguez, CA
Crouse-Hinds by Eaton	Syracuse, NY
Eaton's B-Line Business	Highland, IL
ERICO	Solon, OH
Hubbell Incorporated	Shelton, CT
IPEX Management Inc.	Mississauga, ON, Canada
Legrand/Pass & Seymour	Syracuse, NY
Producto Electric Corporation	Orangeburg, NY
Progressive Machine Die, Inc.	Walton Hills, OH
Steel Electric Products Company, Inc.	Brooklyn, NY
Thomas & Betts, a Member of the ABB Group	Memphis, TN

CONTENTS

Foreword	i
Section 1 GENERAL	1
1.1 SCOPE	1
1.2 NORMATIVE REFERENCES.....	1
1.3 UNITS OF MEASUREMENT	2
1.4 DEFINITIONS	3
Section 2 GENERAL REQUIREMENTS	6
2.1 GENERAL.....	6
2.1.1 Applicability.....	6
2.1.2 Assembly and Mechanical Protection	6
2.1.3 Materials	6
2.1.4 Thread Form and Dimensions.....	7
2.1.5 Resistance to Corrosion	7
2.1.6 Electrical Protection.....	7
2.1.7 Environmental Classifications.....	7
2.1.8 Marking.....	8
2.2 FITTINGS—General.....	8
2.2.1 Functionality	8
2.2.2 Wall Thickness	8
2.2.3 Connectors	8
2.2.4 Couplings.....	9
2.2.5 Thread Form and Dimensions.....	9
2.3 CAST METAL BOXES, JUNCTION BOXES, PULL BOXES and CONDUIT BODIES— General.....	9
2.3.1 Openings	9
2.3.2 Conduit Bodies Used as Fittings	9
2.3.3 Conduit Bodies Used as Boxes.....	9
2.3.4 Conduit Entries	9
2.3.5 Wall Thickness	10
2.3.6 Resistance to Corrosion	10
Section 3 SPECIFIC REQUIREMENTS	14
3.1 GENERAL.....	14
3.1.1 Applicability.....	14
3.1.2 Functionality	14
3.1.3 Offset and Angle Fittings	14
3.2 FITTINGS—SPECIFIC	14
3.2.1 Fittings for Threaded and Unthreaded Non-flexible Metal Circular Raceways (Rigid Metal Conduit, Intermediate Metal Conduit, and Electrical Metallic Tubing).....	14
3.2.2 Fittings for use with Flexible Metal Conduit.....	15
3.2.3 Fittings for Use with Armored Cable.....	15
3.2.4 Fittings for Use with Metal-clad Cable.....	16
3.2.5 Fittings for Use with Mineral-insulated Cable	16
3.2.6 Fittings for use with Liquidtight Flexible Metal Conduit	16
3.2.7 Fittings for Use with Liquidtight Flexible Nonmetallic Conduit.....	17
3.2.8 Locknuts Provided with Fittings.....	17
3.2.9 Conduit Locknuts.....	17
3.2.10 Bushings.....	17
3.2.11 Marking.....	18
3.2.12 Ground Clamps	18

3.2.13	Pulling, Strain Relief, and Support Grips	18
3.2.14	Reducing Washers	18
3.2.15	Service-entrance Heads, Caps	18
3.2.16	Sill Plates	18
3.2.17	Bushings for Use in Metal Studs	19
3.2.18	Closure Plugs and Plates	19
3.3	OUTLET BOXES, CONDUIT BODIES, JUNCTION BOXES, PULL BOXES, AND COVERS—SPECIFIC	19
3.3.1	Marking	19
3.3.2	Cast Metal Outlet Boxes	19
3.3.3	Conduit Bodies	21
3.3.4	Junction and Pull Boxes	21
Section 4	DESIGN TESTS	29
4.1	GENERAL	29
4.1.1	Design Tests	29
4.1.2	Test Sampling	29
4.1.3	Nonmetallic Materials	29
4.2	MECHANICAL PROTECTION	29
4.2.1	Assembly Test (2.1.2.2)	29
4.2.2	Rod Entry Test (2.2.3.5)	29
4.2.3	Mechanical Performance Testing Sequences	29
4.3	ELECTRICAL PROTECTION	30
4.3.1	Fault Current Test (2.1.6.1)	30
4.3.2	Electrical Continuity Test (2.1.6.2)	30
4.4	ENVIRONMENTAL CLASSIFICATION	30
4.4.1	Wet Locations Test (2.1.7.1)	30
4.4.2	Concrete Test (2.1.7.2)	30
4.4.3	Oil Spray Test (2.1.7.3)	30
4.4.4	Type-rated Fittings and Boxes (2.1.7.4)	30
Section 5	MANUFACTURING STANDARDS	31
5.1	THREADS FOR FITTINGS, CAST METAL BOXES, AND CONDUIT BODIES	31
5.1.1	Fittings and Conduit Entries with Internal Tapered Threads	31
5.1.2	Fittings and Conduit Entries with Internal Straight Threads	31
5.1.3	Fittings with External Straight Threads	32
5.1.4	Fittings with External Tapered Threads	32
5.2	KNOCKOUT DIMENSIONS	32
5.3	DIMENSIONS OF FLAT SURFACES SURROUNDING KNOCKOUTS	32
Appendix A	FAMILY TREE OF THE CONDUIT FITTINGS MANUFACTURING INDUSTRY	40
Appendix B	GAUGING PRACTICE	41
Appendix C	ALTERNATIVE KNOCKOUT DIMENSIONS	42
Figures		
Figure 1	Tangential-type Screw	24
Figure 2	Radial-type Screw	24
Figure 3	Basic Dimensions of Internal Straight Pipe Threads for Locknuts for Use with Electrical Connectors Having Type NPT Short Tapered External Threads or Type NPSM Straight External Threads	25
Figure 4	Basic Dimensions and Dimensions of Internal Straight Pipe Threads for Conduit Locknuts ..	26
Figure 5	Configuration of Single-gang FS and FD Box Face	27
Figure 6	Straight Pull Type C	28
Figure 7	Angle Pull Entry Opposite Removable Cover Type LB	28
Figure 8	Flat Surfaces Surrounding Knockouts	36

Figure 9 NPT Male to NPT Female Thread Engagement Trade Sizes $\frac{1}{2}$ and $\frac{3}{4}$;
14 Threads per Inch (Based on Male NPT Thread Gauging of $L_1 + 0$ [Flush]) 37

Figure 10 NPT Male to NPT Female Thread Engagement Trade Sizes 1, $1\frac{1}{4}$, $1\frac{1}{2}$, and 2;
 $11\frac{1}{2}$ Threads per Inch (Based on Male NPT Thread Gauging of $L_1 + 0$ [Flush]) 37

Figure 11 NPT Male to NPT Female Thread Engagement Trade Sizes $2\frac{1}{2}$, 3, $3\frac{1}{2}$, 4, 5, and 6;
8 Threads per Inch (Based on Male NPT Thread Gauging of $L_1 + 0$ [Flush]) 38

Tables

Table 1 Trade Size and Metric Designators..... 5

Table 2 Standard Assembly Torque Values for Conduit and Cable Fittings 11

Table 3 Inside Diameter of Throats and End Stops for Fittings and Bushings 11

Table 4 Thickness of Zinc Corrosion Protective Coating 12

Table 5 Wall Thickness of Fittings..... 12

Table 6 Metal Thickness 12

Table 7 Minimum Thread Projection of Box Connectors..... 13

Table 8 Minimum Wall Thickness at Tapped Holes for Conduit 13

Table 9 Diameter of Plug Go-gauge 22

Table 10 Radius of Bend of Angle Fittings 22

Table 11 Outside Diameter of Flexible Metal Conduit Fitting of the Screw-in-Type 22

Table 12 Armored Cable Bushing Dimensions 23

Table 13 Distance from Removable Cover to Opposite Wall with Raceway Opening 23

Table 14 Number of Turns Past L_1 Gauging Notch of Working NPT Plug Gauge for NTC Threaded
Conduit Entries..... 33

Table 15 Number of Turns Past L_1 Gauging Notch of Working NPT Plug Gauge for NTCM Threaded
Conduit Entries..... 33

Table 16 Minimum Depth to Integral Bushings 34

Table 17 Gauging Requirements for External Tapered Threads for Conduit Fittings for Use with
Threaded Rigid Metal Conduit Couplings, Threaded Intermediate Metal Conduit Couplings,
or Other Electrical Fittings Having Tapered or Straight Internal Threads (Cut Threads—for
Ordinary Location Applications Only)..... 35

Table 18 Maximum Number of Threads in the Wall of a Cast Metal Box Having Through-threaded
Entries 35

Table 19 Compatibility of Knockout Dimensions with Locknuts, Bushings, and Metal Conduit (IMC
or Rigid) to Assure Coordination** 39

< This page intentionally left blank. >

Section 1 GENERAL

1.1 SCOPE

This Standards Publication covers fittings that are a part of electrical raceway systems designed for use as intended by the requirements of the *National Electrical Code*[®] (*NEC*), NFPA 70. Specifically, this standard covers fittings for use with non-flexible tubular raceways: Rigid and Intermediate Metal Conduit and Electrical Metallic Tubing. Also included are fittings for use with flexible conduit and cable raceways, including: Flexible Metal Conduit and liquidtight flexible conduits, Armored Cable, Metal Clad Cable, Tray Cable, Mineral Insulated Cable, Flexible Cord, Nonmetallic Sheathed Cable, and Service Entrance Cable. The Family Tree of the Conduit Fittings Industry is provided for reference in Appendix A.

This standard also includes cast metal outlet boxes and covers, as well as conduit bodies and covers, which when designed for the purpose, serve as a box intended to house conductor splices and/or wiring devices; and cast metal junction boxes, pull boxes, and covers.

This standard does not include standard conduit couplings of the type provided with lengths of Rigid and Intermediate Metal Conduit, or threaded conduit nipples, or threaded or unthreaded factory-made bends derived from Rigid and Intermediate Metal Conduit or Electrical Metallic Tubing.

This standard does not apply to fittings, boxes, or enclosures that are for use in Class I, Division 1; Class II, Division 1; Class III, Division 1; Class I, Zones 0, 1, 2; Zones 20, 21, or 22 hazardous (classified) locations. Exceptions are those ordinary (unclassified) location fittings and enclosures that are specifically permitted by the *NEC* in these locations.