

NEMA IA 2.5-2005

PROGRAMMABLE  
CONTROLLERS—

PART 5:  
COMMUNICATIONS



**NEMA Standards Publication IA 2.5-2005**

**(Adoption of IEC Publication 61131-5)**

*Programmable Controllers—  
Part 5: Communications*

*Published by:*

**National Electrical Manufacturers Association**

1300 North 17th Street, Suite 1752

Rosslyn, Virginia 22209

[www.nema.org](http://www.nema.org)

© Copyright 2005 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

## **NOTICE AND DISCLAIMER**

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

**CONTENTS**

	<b>Page</b>
Foreword .....	ii
Referenced Standards .....	iv
Amendments.....	v
IEC 61131-5 .....	1

## Foreword

This Standards Publication is a NEMA Adoptive Standard based on Part 5 of IEC 61131, *Programmable Controllers*.

This Standards Publication was prepared by a technical committee of the NEMA Automation Products and Systems Section. It was approved in accordance with the bylaws of NEMA and supersedes NEMA Standards Publication ICS 3-1988, Part 3-304.

This Standards Publication provides practical information concerning ratings, construction, test, performance, and manufacture of industrial control equipment. These standards are used by the electrical industry to provide guidelines for the manufacture and proper application of reliable products and equipment and to promote the benefits of repetitive manufacturing and widespread product availability.

NEMA Standards represent the result of many years of research, investigation, and experience by the members of NEMA, its predecessors, its Sections and Committees. They have been developed through continuing consultation among manufacturers, users, and national engineering societies and have resulted in improved serviceability of electrical products with economies to manufacturers and users.

One of the primary purposes of this Standards Publication is to encourage the production of reliable control equipment which, in itself, functions in accordance with these accepted standards. Some portions of these standards, such as electrical spacings and interrupting ratings, have a direct bearing on safety; almost all of the items in this publication, when applied properly, contribute to safety in one way or another.

Properly constructed industrial control equipment is, however, only one factor in minimizing the hazards which may be associated with the use of electricity. The reduction of hazard involves the joint efforts of the various equipment manufacturers, the system designer, the installer, and the user. Information is provided herein to assist users and others in the proper selection of control equipment.

The industrial control manufacturer has limited or no control over the following factors which are vital to safe installation:

- environmental conditions
- system design
- equipment selection and application
- installation
- operating practices
- maintenance

This publication is not intended to instruct the user of control equipment with regard to these factors except insofar as suitable equipment to meet needs can be recognized in this publication and some application guidance is given.

This Standards Publication is necessarily confined to defining the construction requirements for industrial control equipment and to providing recommendations for proper selection for use under normal or certain specific conditions. Since any piece of industrial control equipment can be installed, operated, and maintained in such a manner that hazardous conditions may result, conformance with this publication does not by itself assure a safe installation. When, however, equipment conforming with these standards is properly selected and is installed in accordance with the National Electrical Code and properly maintained, the hazards to persons and property will be reduced.

To continue to serve the best interests of users, NEMA is actively cooperating with other standardization organizations in the development of simple and more universal metrology practices. In this Standards Publication, the U.S. customary units are gradually being supplemented by those of the modernized metric system known as the International Systems of Units (SI). This transition involves no changes in standard dimensions, tolerances, or performance specifications.

NEMA Standards Publications are subject to periodic review. They are revised frequently to reflect user input and to meet changing conditions and technical progress. Users should secure the latest editions.

Inquiries, comments, and proposed or recommended revisions should be submitted to the concerned NEMA product subdivision by contacting the:

Vice President, Technical Services  
National Electrical Manufacturers Association  
1300 North 17th Street  
Rosslyn, Virginia 22209

## Referenced Standards

The following standards contain provisions which, through reference in this text, constitute provisions of this NEMA Standards Publication. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below.

**International Electrotechnical Commission**  
1, rue de Varembé  
Geneva, Switzerland

IEC 61131-5

*Programmable Controllers—Part 5: Communications*



## **Amendments**

IEC 61131-5, *Programmable Controllers—Part 5: Communications*, is adopted in its entirety.  
NEMA Adoptive Standard

Where a conflict exists between the provisions of IA 2.5 and other NEMA Standards Publications, the provisions of IA 2.5 shall govern in the area of programmable controllers and their associated peripherals.  
NEMA Standard

< This page is intentionally left blank. >

# INTERNATIONAL STANDARD

**IEC**  
**61131-5**

First edition  
2000-11

---

---

## **Programmable controllers –**

### **Part 5: Communications**

*Automates programmables –*

*Partie 5:  
Communications*



Reference number  
IEC 61131-5:2000(E)

## Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

## Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

## Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site ([www.iec.ch](http://www.iec.ch))**
- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site ([www.iec.ch/catfig-e.htm](http://www.iec.ch/catfig-e.htm)) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.
- **IEC Just Published**

This summary of recently issued publications ([www.iec.ch/JP.htm](http://www.iec.ch/JP.htm)) is also available by email. Please contact the Customer Service Centre (see below) for further information.
- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: [custserv@iec.ch](mailto:custserv@iec.ch)  
Tel: +41 22 919 02 11  
Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

# IEC 61131-5

First edition  
2000-11

---

---

## Programmable controllers –

### Part 5: Communications

*Automates programmables –*

*Partie 5:  
Communications*

© IEC 2000 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission 3, rue de Varembé Geneva, Switzerland  
Telefax: +41 22 919 0300 e-mail: [inmail@iec.ch](mailto:inmail@iec.ch) IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE

X

*For price, see current catalogue*

## CONTENTS

	Page
FOREWORD .....	6
 Clause	
1 Scope .....	8
2 Normative references .....	8
3 Definitions .....	9
4 Symbols and abbreviations .....	11
5 Models .....	11
5.1 PC network communication model .....	11
5.2 PC functional model .....	12
5.3 PC hardware model .....	14
5.4 Software model .....	14
6 PC communication services .....	15
6.1 PC subsystems and their status .....	15
6.2 Application specific functions .....	22
7 PC communication function blocks .....	28
7.1 Overview of the communication function blocks .....	28
7.2 Semantic of communication FB parameters .....	29
7.3 Device verification .....	34
7.4 Polled data acquisition .....	38
7.5 Programmed data acquisition .....	41
7.6 Parametric control .....	51
7.7 Interlocked control .....	54
7.8 Programmed alarm report .....	61
7.9 Connection management .....	69
7.10 Example for the use of communication function blocks .....	73
8 Compliance and implementer specific features and parameters .....	76
8.1 Compliance .....	76
8.2 Implementation specific features and parameters .....	77
 Annex A (normative) Mapping to ISO/IEC 9506-5 .....	 78
Annex B (normative) PC behavior using ISO/IEC 9506-2 .....	98
 Figure 1 – Scope of this part of IEC 61131 .....	 8
Figure 2 – PC communication model .....	12
Figure 3 – Programmable controller functional model .....	13
Figure 4 – Programmable controller hardware model .....	14
Figure 5 – PC software model .....	15
Figure 6 – Programmable controller power supply .....	19
Figure 7 – Type description of status information .....	21
Figure 8 – Interlocked control timeline .....	24
Figure 9 – Function REMOTE_VAR .....	31

Figure 10 – Principle of status signalling .....	32
Figure 11 – Timing diagram of the ERROR and STATUS outputs .....	32
Figure 12 – STATUS function block .....	34
Figure 13 – USTATUS function block .....	35
Figure 14 – Timing diagram of the STATUS function block .....	35
Figure 15 – State diagram of STATUS function block .....	36
Figure 16 – State diagram of USTATUS function block .....	37
Figure 17 – READ function block .....	39
Figure 18 – Timing diagram of READ function block .....	39
Figure 19 – State diagram of READ function block .....	40
Figure 20 – Programmed data acquisition data flow .....	41
Figure 21 – USEND function block .....	42
Figure 22 – URCV function block .....	42
Figure 23 – Timing diagram of USEND and URCV function blocks .....	43
Figure 24 – State diagram of USEND function block .....	43
Figure 25 – State diagram of URCV function block .....	45
Figure 26 – BSEND function block .....	47
Figure 27 – BRCV function block .....	48
Figure 28 – Timing diagram of BSEND and BRCV function blocks .....	48
Figure 29 – State diagram of BSEND function block .....	49
Figure 30 – State diagram of BRCV function block .....	50
Figure 31 – WRITE function block .....	52
Figure 32 – Timing diagram of WRITE function block .....	53
Figure 33 – State diagram of WRITE function block .....	53
Figure 34 – SEND function block .....	55
Figure 35 – RCV function block .....	56
Figure 36 – Timing diagram of SEND and RCV function blocks .....	57
Figure 37 – State diagram of SEND function block .....	58
Figure 38 – State diagram of RCV function block .....	60
Figure 39 – NOTIFY function block .....	62
Figure 40 – ALARM function block .....	63
Figure 41 – Timing diagram of ALARM function block .....	64
Figure 42 – State diagram of NOTIFY function block .....	65
Figure 43 – State diagram of ALARM function block .....	67
Figure 44 – CONNECT function block .....	69
Figure 45 – Timing diagram of CONNECT function block .....	70
Figure 46 – State diagram of CONNECT function block .....	71
Figure 47 – Example in function block diagram language .....	76
Table 1 – Status presenting entities .....	16
Table 2 – PC summary status .....	17
Table 3 – Status of I/O subsystem .....	18
Table 4 – Status of processing unit .....	18

Table 5 – Status of power supply .....	19
Table 6 – Status of memory .....	19
Table 7 – Status of communication subsystem .....	20
Table 8 – Status of implementer specific subsystem .....	20
Table 9 – Presentation of status information .....	21
Table 10 – Device verification features .....	23
Table 11 – Data acquisition features .....	23
Table 12 – Control features .....	24
Table 13 – Alarm reporting features .....	25
Table 14 – Startable and stoppable units .....	25
Table 15 – Meaning of I/O State .....	26
Table 16 – I/O state .....	26
Table 17 – Execution and I/O control features .....	26
Table 18 – Loadable units .....	27
Table 19 – Application program transfer features .....	27
Table 20 – Connection management features .....	28
Table 21 – Overview of the communication function blocks .....	28
Table 22 – Semantic of communication FB parameters .....	30
Table 23 – Values of the SCOPE parameter .....	31
Table 24 – Value and interpretation of the STATUS output .....	33
Table 25 – Transitions of the STATUS state diagram .....	36
Table 26 – Action table for STATUS state diagram .....	36
Table 27 – Transitions of USTATUS state diagrams .....	37
Table 28 – Action table of USTATUS state diagram .....	37
Table 29 – Transitions of the READ state diagram .....	40
Table 30 – Action table for READ state diagram .....	41
Table 31 – Transitions of the USEND state diagram .....	44
Table 32 – Action table for USEND state diagram .....	44
Table 33 – Transitions of URCV state diagrams .....	45
Table 34 – Action table of URCV state diagram .....	46
Table 35 – Transitions of the BSEND state diagram .....	49
Table 36 – Action table for BSEND state diagram .....	50
Table 37 – Transitions of BRCV state diagrams .....	51
Table 38 – Action table of BRCV state diagram .....	51
Table 39 – Transitions of the WRITE state diagram .....	54
Table 40 – Action table for WRITE state diagram .....	54
Table 41 – Transitions of the SEND state diagram .....	58
Table 42 – Action table for SEND state diagram .....	59
Table 43 – Transitions of RCV state diagrams .....	60
Table 44 – Action table of RCV state diagram .....	61
Table 45 – Transitions of the NOTIFY state diagram .....	65
Table 46 – Action table for NOTIFY state diagram .....	66
Table 47 – Transitions of the ALARM state diagram .....	68



Table 48 – Action table for ALARM state diagram .....	68
Table 49 – Transitions of the CONNECT state diagram .....	72
Table 50 – Action table for CONNECT state diagram .....	73
Table 51 – Table titles and relevant tables for compliance.....	76
Table 52 – Implementation specific features and parameters .....	77
Table A.1 – Type description mapping .....	81
Table A.2 – Mapping of the SCOPE and SC_ID parameter .....	81
Table A.3 – Size prefix of direct representation .....	82
Table A.4 – Transition mapping of the STATUS state diagram .....	84
Table A.5 – Action mapping for STATUS state diagram.....	84
Table A.6 – Transition mapping of USTATUS state diagram.....	84
Table A.7 – Action mapping of USTATUS state diagram .....	84
Table A.8 – Transition mapping of the READ state diagram.....	85
Table A.9 – Action mapping for READ state diagram.....	85
Table A.10 – Transition mapping of the USEND state diagram .....	86
Table A.11 – Action mapping for USEND state diagram .....	86
Table A.12 – Transition mapping of URCV state diagram .....	86
Table A.13 – Action mapping for URCV state diagram.....	87
Table A.14 – Transition mapping of the BSEND state diagram .....	87
Table A.15 – Action mapping for BSEND state diagram.....	88
Table A.16 – Transition mapping of BRCV state diagram .....	88
Table A.17 – Action mapping for BRCV state diagram.....	89
Table A.18 – Transition mapping of the WRITE state diagram .....	90
Table A.19 – Action mapping for WRITE state diagram .....	90
Table A.20 – Transition mapping of the SEND state diagram.....	90
Table A.21 – Action mapping for SEND state diagram.....	91
Table A.22 – Transition mapping of RCV state diagram.....	91
Table A.23 – Action mapping of RCV state diagram .....	92
Table A.24 – Transition mapping of the NOTIFY state diagram.....	94
Table A.25 – Action mapping for NOTIFY state diagram.....	94
Table A.26 – Transition mapping of the ALARM state diagram .....	95
Table A.27 – Action mapping for ALARM state diagram.....	95
Table A.28 – Transitions of the CONNECT state diagram.....	96
Table A.29 – Action mapping for CONNECT state diagram.....	96
Table A.30 – Implementation specific features and parameters .....	97
Table B.1 – CreateProgramInvocation service defaults.....	98
Table B.2 – Program Invocation service defaults for I/O State parameter .....	98
Table B.3 – Implementation specific features and parameters .....	99

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## PROGRAMMABLE CONTROLLERS –

## Part 5: Communications

## FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61131-5 has been prepared by subcommittee 65B: Devices, of IEC technical committee 65: Industrial-process measurement and control.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/411/FDIS	65B/420/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 3.

This part should be read in conjunction with the other parts of IEC 61131. IEC 61131 consists of the following parts under the general title: *Programmable controllers*.

Part 1:1992, General information.

Part 2:1992, Equipment requirements and tests.

Part 3:1993, Programming languages.

Part 4:1994, User guidelines (published as technical report IEC TR 61131-4)

Part 5:2000, Communications

Part 8:2000, Guidelines for the application and implementation of programming languages (published as technical report IEC TR 61131-8)

Annexes A and B form an integral part of this standard.

Annex C is for information only.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

The committee has decided that the contents of this publication will remain unchanged until 2006. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

## PROGRAMMABLE CONTROLLERS –

### Part 5: Communications

#### 1 Scope

This part of IEC 61131 specifies communication aspects of a programmable controller. It specifies from the viewpoint of a PC how any device can communicate with a PC as a server and how a PC can communicate with any device. In particular, it specifies the behavior of the PC as it provides services on behalf of other devices and the services the PC application program can request from other devices. It is not intended to specify how any device can communicate with any device using a PC as a router or gateway. The behavior of the PC as a communication client and server is specified independent of the particular communication subsystem, but the communication functionality may be dependent on the capabilities of the communication subsystem used.




Figure 1 – Scope of this part of IEC 61131

The scope of this part is a subset of the "communication model" shown in figure 2 of IEC 61131-3; namely figures 2c and 2d are included in the scope of this part. Additionally, the means defined in this part of IEC 61131 may be used for communications within a program or between programs.

The mapping of the PC behavior to some particular communications subsystems is provided in the annexes.

#### 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this part of IEC 61131. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this part of IEC 61131 are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

IEC 60050-351:1998, *International Electrotechnical Vocabulary – Part 351: Automatic control*

IEC 61131-1:1992, *Programmable controllers – Part 1: General Information*

IEC 61131-2:1992, *Programmable controllers – Part 2: Equipment requirements and tests*

IEC 61131-3:1993, *Programmable controllers – Part 3: Programming languages*

ISO/IEC 2382-1:1993, *Information technology – Vocabulary – Part 1: Fundamental terms*

ISO/IEC 9506-1:1990, *Industrial automation systems – Manufacturing Message Specification – Part 1: Service definition*