NEMA OS 4

Requirements for Air-Sealed Boxes for Electrical and Communication Applications

Published by

National Electrical Manufacturers Association 1300 North 17th Street, Suite 900 Rosslyn, Virginia 22209

www.nema.org

© 2016 National Electrical Manufacturers Association. All rights, including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American copyright conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health- or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

| Foreword | | .ii |
|-----------|----------------------------------|-----|
| Section 1 | General | 1 |
| 1.1 | Scope | 1 |
| 1.2 | References | 1 |
| 1.3 | Definitions | 2 |
| Section 2 | Construction | 3 |
| Section 3 | Performance Criteria | 4 |
| 3.1 | Air Leakage Performance | 4 |
| Section 4 | Test Method | 5 |
| 4.1 | Procedure | 5 |
| | 4.1.1 General | 5 |
| | 4.1.2 Sampling | 5 |
| 4.2 | Sample preparation | 5 |
| | 4.2.1 Assembly of Wiring Methods | 5 |
| | 4.2.2 Mounting in Test Chamber | 5 |
| 4.3 | Air Flow Measurement | 7 |
| Section 5 | Marking and Documentation | 8 |
| 5.1 | Product Marking | 8 |
| 5.2 | Installation Instructions | 8 |

FIGURES

| 1 | Inside Chamber Door with Boxes Mounted | 6 |
|---|--|-----|
| 2 | Inside Chamber Door with Boxes Mounted | 6 |
| 3 | Block Diagram of Blower Door/Duct Leakage Style Test Apparatus | A-1 |
| 4 | Fabricated Test Chamber with Test Panel Installed | A-2 |
| 5 | Air Exhaust/Calibration Chamber | A-2 |
| 6 | Air Diffuser in Test Chamber | A-3 |

ANNEXES

| Α | Description of Typical Blower Door/Duct Leakage Style Apparatus for Internal Air Leakage | |
|---|--|-----|
| | Measurements | A-1 |
| В | Applicable Building and Energy Codes and Other Resources | B-1 |

Foreword

Building and energy codes for energy-efficient construction place a high priority on preserving the building thermal envelope. Installation of doors; windows; and mechanical, electrical, and other systems within exterior walls and ceilings and other separations between conditioned and unconditioned spaces results in penetrations in the air barrier. When these penetrations are not effectively sealed, the air barrier is compromised, resulting in air leakage, both in and out, which increases the energy usage necessary to maintain the desired condition of the air inside the structure.

Besides external walls and ceilings in a building, uninsulated interior walls and interior floor-ceiling cavities not designed specifically for air exchange, present pathways for air leakage. Even though air barriers are not commonly installed here, consideration should be given to using effective sealing techniques at wall, ceiling, and floor penetrations in these areas.

Sealing air-barrier penetrations is not always as simple as applying more insulation, caulk, or expanding foam. Products such as electrical outlet boxes, having design features that address effective sealing of the air-barrier penetrations, also reduce potentially undesirable effects that can result from the use of unspecified sealing techniques.

Annex B of this standard provides pertinent references to the applicable building and energy codes and to other helpful references.

In the preparation of this standards publication, input of users and other interested parties has been sought and evaluated. Inquiries, comments, and proposed or recommended revisions should be submitted by contacting:

Senior Technical Director, Operations National Electrical Manufacturers Association 1300 North 17th Street, Suite 900 Rosslyn, Virginia 22209

This standards publication was developed by the Outlet and Switch Box Section. Section approval does not necessarily imply that all section members voted for its approval or participated in its development. At the time it was approved, the section was composed of the following members:

2D2C, Inc.—<u>http://www.2d2c.com</u>—Lincolnshire, IL
Allied Moulded Products, Inc.— <u>http://www.alliedmoulded.com</u>—Bryan, OH
Arlington Industries, Inc.—<u>http://www.aifittings.com</u>—Scranton, PA
Eaton's B-Line Business—<u>http://www.cooperbline.com</u>—Highland, IL
Crouse-Hinds by Eaton—<u>http://www.crouse-hinds.com</u>—Syracuse, NY
Emerson Automation Solutions—<u>http://www.emersonindustrial.com/en-US/businesses/Pages/appletongroup.aspx</u>—Rosemont, IL
Pentair Engineered Electrical & Fastening Solutions—<u>http://www.erico.com</u>—Solon, OH
Hubbell Incorporated—<u>http://www.hubbell.com</u>—Shelton, CT
Legrand/Pass & Seymour—<u>http://www.passandseymour.com</u>—Syracuse, NY
RACO—<u>http://www.hubbell.com/Electrical/Raco.aspx</u>—South Bend, IN
Sigma Electric Manufacturing Corporation—<u>http://www.sigmaelectric.com</u>—Garner, NC
Southwire Company—<u>http://www.southwire.com/</u>—Carrollton, GA
Thomas & Betts, A Member of the ABB Group—<u>http://www.tnb.com</u>—Memphis, TN
Wiremold/Legrand—<u>http://www.wiremold.com</u>—West Hartford, CT

Section 1 General

1.1 Scope

This standard establishes a performance test and classification scheme for outlet boxes: wall boxes, ceiling boxes, and floor boxes used for electrical and communication applications having design provisions for reducing the flow of air (air leakage) through the box and at its installed interface with the building structure, when installed as intended for normal use as instructed by the manufacturer.

The classification scheme in this standard meets the intent of the International Energy Conservation Code (IECC) and covers boxes installed in walls, ceilings, and floors where an air barrier is required.

This standard does not cover design or performance of electrical outlet boxes that are addressed in ANSI/UL 514A, CSA C22.2 No.18.1, NMX-J-023-ANCE, ANSI/UL 514C, CSA C22.2 No.18.2, ANSI/NEMA OS1, ANSI/NEMA OS2, IEC 60670-1, IEC 60670-21, or IEC 60670-23.

This standard does not cover environmental classifications for boxes or enclosures addressed in ANSI/UL 50E, CSA C22.2 No. 94.2, or NMX-J-235/2-ANCE.