



**Approved as an American National Standard
ANSI Approval Date: April 27, 2021**

ANSI/NEMA WC 70/ICEA S-95-658-2021
Power Cables Rated 2000 Volts or Less for the Distribution of Electrical Energy

Prepared by:

Insulated Cable Engineers Association, Inc.

www.icea.net

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

©2021 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

©2021 Insulated Cable Engineers Association, Inc. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the international and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) and the Insulated Cable Engineers Association Inc. (ICEA) Standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus Standards development process. This process brings together persons who have an interest in the topic covered by this publication. While NEMA and ICEA administers the process and establishes rules to promote fairness in the development of consensus, they do not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its Standards and guideline publications.

NEMA and ICEA disclaims liability for personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA and ICEA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your purposes or needs. NEMA and ICEA do not undertake to guarantee the performance of any individual manufacturer's or seller's products or services by virtue of this Standard or guide.

In publishing and making this document available, NEMA and ICEA are not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA and ICEA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other Standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA and ICEA have no power, nor do they undertake to police or enforce compliance with the contents of this document. NEMA and ICEA do not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and ICEA and is solely the responsibility of the certifier or maker of the statement.

Contents

Section 1 General	1
1.1 Scope	1
1.2 General Information	1
1.3 Information to Be Supplied by Purchaser	1
1.3.1 Characteristics of System on Which Cable Is to Be Used	1
1.3.2 Quantities and Description of Cable	2
1.4 Definitions	2
1.5 Abbreviations and Symbols	4
Section 2 Conductor	5
2.0 General.....	5
2.1 Physical and Electrical Properties.....	5
2.1.1 Copper Conductors	5
2.1.2 Aluminum Conductors	5
2.1.3 Flexible Conductors	6
2.2 Conductor Size Units	6
2.3 Conductor DC Resistance per Unit Length.....	6
2.3.1 Direct Measurement of DC Resistance	6
2.3.2 Calculation of DC Resistance per Unit Length	6
2.4 Conductor Diameter	7
Section 3 Insulation	18
3.1 Material.....	18
3.2 Insulation Compound Levels.....	18
3.3 Insulation Thicknesses.....	18
3.3.1 Thickness Determination	19
3.4 Additional Insulation Thickness for Non-Sheathed Submarine Cables	19
3.5 Repairs.....	19
3.6 Insulation Compound Classes and Requirements.....	19
3.6.1 Insulation Compound Classes and Characteristics.....	19
3.6.2 Voltage Tests.....	19
3.6.3 Insulation Resistance	19
3.6.4 Flame Tests	20
Section 4 Coverings	30
4.1 Jackets	30
4.1.1 Crosslinked and Thermoplastic Jackets—General	30
4.1.2 Optional Requirements	31
4.1.3 Separator Under Jacket.....	31
4.1.4 Repairs	31
4.1.5 Jacket Thickness	35
4.1.6 Irregularity Inspection of Jackets over Cable	36
4.2 Metallic and Associated Coverings	36
4.2.1 General	36
4.3 Division I.....	38
4.3.1 Smooth Metallic Sheaths.....	38
4.3.2 Flat Steel Tape Armor	40
4.3.3 Interlocked Metal Tape Armor	42
4.3.4 Continuously Corrugated Metal Armor	43
4.3.5 Galvanized Steel Wire Armor	44
4.3.6 Bedding over Cable Cores to Be Metallic Armored.....	46
4.3.7 Outer Servings.....	47
4.3.8 Crosslinked Jackets over Metallic Coverings (Sheaths and Armors).....	48
4.3.9 Thermoplastic Jackets over Metallic Coverings (Sheaths or Armors).....	49
4.4 Division II.....	50

4.4.1	Borehole Cable (Suspended at One End Only)	50
4.4.2	Dredge Cable	51
4.4.3	Shaft Cable	52
4.4.4	Vertical Riser Cable	52
4.5	Division III	53
4.5.1	Buried Land Cables	53
Section 5 Assembly, Fillers, Conductor Identification, Grounding Conductors, and Shielding		54
5.1	Assembly of Multiple-Conductor Cables	54
5.1.1	Multiple-Conductor Round Cables with an Overall Covering	54
5.1.2	Multiple-Conductor Assemblies Without Overall Covering	54
5.1.3	Flat Twin Cables	55
5.2	Fillers	55
5.3	Conductor Identification	55
5.4	Grounding Conductors	55
5.5	Shielding	55
5.5.1	General	55
5.5.2	Metal Tapes	56
Section 6 Production Tests and Test Methods		57
6.1	General	57
6.1.1	Testing and Test Frequency	57
6.1.2	Test Methods	57
6.1.3	Number of Test Specimens from Samples	59
6.2	Thickness Measurements	59
6.2.1	Beddings and Servings	59
6.2.2	Other Components	59
6.3	Samples and Specimens for Physical and Aging Tests	59
6.3.1	General	59
6.3.2	Sampling	59
6.3.3	Size of Test Specimens	59
6.3.4	Specimens with Jackets	60
6.3.5	Specimen Surface Irregularities	60
6.3.6	Specimens for the Aging Tests	61
6.3.7	Calculation of Area of Test Specimens	61
6.4	Aging Tests	62
6.4.1	Air Oven Aging Test	62
6.4.2	Oil Immersion Test	62
6.5	Heat Shock Test	62
6.6	Cold-Bend Test	62
6.7	Tightness of Polyethylene Jacket to Sheath Test	63
6.8	Hot Creep Test	63
6.9	Wrap Test for Nylon-Covered Insulated Conductors	63
6.10	Electrical Tests on Completed Cables	63
6.10.1	Voltage Tests	63
6.10.2	Insulation Resistance	65
6.10.3	Shield Continuity	65
6.11	Retests	65
6.11.1	Physical and Aging Properties and Thickness	65
6.11.2	Other Tests	66
6.11.3	Conductor Resistance Test	66
Section 7 Qualification Tests		67
7.1	General	67
7.2	Accelerated Water Absorption Test, Electrical Method at 60 Hz	67
7.3	Insulation Resistance Test	67
7.4	Sunlight Resistance Test	67
7.5	Halogen Content of Nonmetallic Elements	67

7.6	Smoke Generation Test	68
7.7	Acid Gas Equivalent Test.....	68
7.8	Environmental Stress Cracking Test.....	68
7.9	Absorption Coefficient.....	68
7.10	Wet Insulation Resistance Stability Test.....	68
7.11	Flame Testing	69
7.11.1	Type A (Single Conductor)	69
7.11.2	Type B (Single Conductor)	69
7.11.3	Tray Cable Flame Test.....	69
7.12	Impact Test	69
7.13	Crush Test.....	71
Section 8 Constructions of Specific Types		73
8.1	Preassembled Aerial Cables.....	73
8.1.1	Scope.....	73
8.1.2	Conductors	73
8.1.3	Insulation	73
8.1.4	Jacket	73
8.1.5	Assembly	73
8.1.6	Messenger	73
8.1.7	Design Criteria.....	73
Section 9 Appendices		74
Appendix A NEMA, ICEA, ASTM, and DOD Standards		74
A.1	NEMA Publications*	74
A.2	ICEA Publications*	74
A.3	ASTM Standards**	74
A.4	Department of Defense Standards	76
Appendix B Definitions of Maximum Temperatures of Insulated Cable Conductors		78
B.1	Maximum Conductor Temperature—Continuous Operation	78
B.2	Maximum Conductor Temperature—Emergency Overload.....	78
B.3	Maximum Conductor Temperature—Short Circuit.....	78
Appendix C Emergency Overloads		79
Appendix D Representative Tensile Strength and Elongation of Nonmagnetic Metals		80
Appendix E Recommended Bending Radii for Cables		81
E.1	Scope	81
E.2	Nonshielded Power Cables Without Metallic Sheath or Armor.....	81
E.3	Nonshielded Cables with Metallic Sheath or Armor.....	81
E.4	Drum Diameters of Reels.....	81
E.5	Installation Temperatures.....	81
Appendix F Additional Conductor Information.....		83
Appendix G Procedure for Determining Dimensional Requirements of Jackets and Associated Coverings		92
G.1	Jacket, Bedding, Sheath, and Armor Thicknesses; Armor Wire Size; and Armor Metal Tape Width	92
G.1.1	The Calculated Diameter over the Single-Conductor Core.....	92
G.1.2	The Calculated Diameter over the Individual Conductor Jacket	92
G.1.3	The Calculated Diameter over the Assembly of Multiple Conductors	92
G.1.4	The Calculated Diameter over a Bedding Layer	93
G.1.5	The Calculated Diameter over Flat Metal Armoring Tapes	93
G.1.6	The Calculated Diameter over an Interlocking or Corrugated Armor	94
G.1.7	The Calculated Diameter over a Smooth Sheath.....	94
G.1.8	The Calculated Diameter over a Steel Armor Wire	94
G.2	Example Calculation	94
Appendix H Acceptance Testing After Installation		96

LIST OF TABLES

Table 2-1 Resistance and Weight Increment Factors*	7
Table 2-2 Schedule for Establishing Maximum Direct Current Resistance per Unit Length of Completed Cable Conductors Listed in Tables 2-4 Through 2-6	8
Table 2-3 Nominal Diameters for Copper and Aluminum Conductors	9
Table 2-3M (Metric) Nominal Diameters for Copper and Aluminum Conductors	11
Table 2-4 Nominal Direct Current Resistance in Ohms per 1000 Feet at 25°C of Solid and Stranded Conductor.....	13
Table 2-4M (Metric) Nominal Direct Current Resistance in Ohms per Kilometer at 25°C of Solid and Stranded Conductor.....	14
Table 2-5 Nominal Direct Current Resistance in Ohms per 1000 Feet at 25°C for Flexible Annealed Copper Conductors	15
Table 2-5M (Metric) Nominal Direct Current Resistance in Ohms per Kilometer at 25°C for Flexible Annealed Copper Conductors	16
Table 2-6* Factors for Determining Nominal Resistance of Stranded Conductors per 1000 Feet at 25°C†	17
Table 3-1 Insulation Compound Ratings.....	21
Table 3-2 Voltage Test Reference Paragraphs	22
Table 3-3 Conductor Sizes, Insulation Thicknesses, and Test Voltages for Class R Insulations	23
Table 3-4 Conductor Sizes, Insulation Thicknesses, and Test Voltages for Class T-4, T-5, T-6, and All Class X and E Insulation.....	24
Table 3-5 Conductor Sizes, Insulation Thickness, and Test Voltages for Class T-3 Polyvinyl Chloride/Nylon-Insulated Power Cables	25
Table 3-6 Conductor Sizes, Insulation Thickness, and Test Voltages for Class T-1 and T-2 Polyvinyl-Chloride-Insulated Power Cables.....	26
Table 3-7 Insulation Requirements	27
Table 3-8 Insulation Compound Requirements	28
Table 4-1 Jacket Requirements	32
Table 4-2 Low Smoke Halogen-Free (LS HF) Jacket Requirements	34
Table 4-3 Jacket Thickness for Single-Conductor Cables.....	35
Table 4-4 Thickness of Optional Jacket on Individual Conductors of Multiple-Conductor Cables Under a Common Jacket	35
Table 4-5 Thickness of Common Overall Jacket of Multiple-Conductor Cable	36
Table 4-6 Irregularity Inspection Test Method	36
Table 4-7 Thickness of Lead Sheath on Unjacketed Cables.....	39
Table 4-8 Thickness of Lead Sheath for Cables Having a Crosslinked or Thermoplastic Jacket over Lead Sheath.....	39
Table 4-9 Thickness of Smooth Aluminum Sheath.....	40
Table 4-10 Width of Steel Tape for Flat Armor (Plain or Zinc Coated).....	41
Table 4-11 Thickness of Steel Tape for Flat Armor (Plain or Zinc Coated).....	41
Table 4-12 Width of Metal Tape for Interlocked Armor.....	42
Table 4-13 Thickness of Metal Tape for Interlocked Armor.....	43
Table 4-14 Minimum Thickness of Metal for Corrugated Armor	44
Table 4-15 Number of Twists (Torsion Test)	45
Table 4-16 Minimum Weights of Zinc Coating	45
Table 4-17 Mandrel Diameter for Adherence of Coating Tests	45
Table 4-18 Size of Galvanized Steel Armor for Submarine Cable.....	46
Table 4-19 Tolerances in Diameter.....	46
Table 4-20 Nominal Thickness of Bedding Under Metallic Armor for Non-Sheathed and Non-Jacketed Cores	47
Table 4-21 Thickness of Servings over Metallic Sheath (Without Metallic Armor).....	48
Table 4-22 Thickness of Extruded Crosslinked and Extruded Thermoplastic Jacket over Metallic Sheath & Armors.....	49

Table 4-23 Jacket Irregularity AC Spark Test Voltage for Nonconducting Jackets*	50
Table 4-24 Size of Galvanized Steel Armor Wire for Borehole Cable	51
Table 4-25 Spacing and Length of Band Servings	51
Table 4-26 Pitch Ratio of Galvanized Wire Armor for Dredge Cable.....	52
Table 4-27 Size of Galvanized Steel Armor Wire for Dredge Cable.....	52
Table 4-28 Size of Galvanized Steel Armor Wire for Shaft Cable and Vertical Riser Cable	52
Table 4-29 Thickness of Jute Bedding and Size of Armor Wire (Division III)	53
Table 5-1 Lay Factors	54
Table 5-2 Grounding Conductor Size for Cables Rated 0-2000 Volts	55
Table 6-1 Summary of Production Tests and Suggested Sampling Frequency Requirements	58
Table 6-2 Mandrel Diameter for Cold-Bend Test.....	62
Table 7-1 Test Samples and Constructions that They Represent.....	70
Table E-1 Nonshielded Power Cables Without Metallic Sheath or Armor	81
Table E-2 Sheathed or Armored Cable Bending Radius	82
Table F-1 Solid Aluminum and Copper Conductors	83
Table F-2 Stranded Class B Aluminum and Copper Conductors	84
Table F-3 Stranded Class C and D Aluminum and Copper Conductors	85
Table F-4 Rope-Lay Aluminum and Copper Conductors, Class G	87
Table F-5 Rope-Lay Aluminum and Copper Conductors, Class H.....	88
Table F-6 Aluminum and Copper Conductors, Class I Each Individual Strand 24 AWG, 0.0201 Inch (0.511 mm).....	89
Table F-7 Copper Conductors, Class K Each Individual Strand 30 AWG, 0.0100 Inch (0.254 mm).....	90
Table F-8 Copper Conductors, Class M Each Individual Strand 34 AWG, 0.0063 Inch (0.160 mm).....	91
Table G-1 Diameter Multipliers for Round Core Cables	93
Table G-2 Armor Tape Thickness Adder	94

Foreword

This Standards publication for *Power Cables Rated 2000 Volts or Less for the Distribution of Electrical Energy* was developed by the Insulated Cable Engineers Association (ICEA) and approved by the National Electrical Manufacturers Association (NEMA).

ICEA/NEMA Standards are adopted in the public interest and are designed to eliminate misunderstanding between the manufacturer and the user and to assist the user in selecting and obtaining the proper product for his particular need. Existence of an ICEA/NEMA Standard does not in any respect preclude the manufacture or use of products not conforming to the Standard. The user of this Standard is cautioned to observe any health or safety regulations and rules relative to the manufacture and use of cable made in conformity with this Standard.

Requests for interpretation of this Standard must be submitted in writing to Insulated Cable Engineers Association, Inc. via www.icea.net.

An official written interpretation will be provided once approved by ICEA and NEMA. Suggestions for improvements gained in the use of this Standard are welcome and should be referred to the ICEA or NEMA.

The Members of the ICEA working group contributing to the writing of this Standard consisted of the following:

J. Armstrong	E. J. Bartolucci, Chairman	
A. Davila	M. Bodziony	W. Crawford
P. Leblanc	B. Fleming	F. Kuchta
B. Miller	C. Lindler	J. Maximo
R. Neumann	J. Mumm	R. Murphy
C. Spradlin	K. Nuckles	K. Porter
T. West	R. Szilagyi	J. Weitzel

This Standard was processed and approved for submittal to ANSI by the NEMA C8 Committee on Insulated Wire and Cables, Excluding Magnet Wire. Committee approval of the Standard does not necessarily imply that all committee Members voted for its approval. At the time it approved this Standard, the C8 committee had the following Members:

Kenneth	Bow	Kable Consult LLC
Lauri	Hiivala	Power Cable Consultant
Trung	Hiu	USDA Rural Development Utilities Programs
Michael	Kinard	Consultant
Anthony	Tassone	UL LLC
Todd	Taylor	Enfinity Engineering
Gerald	Dorna	Belden
Christel	Hunter	Cerrowire
Kevin	Porter	Encore Wire Corporation
Michael	Stover	Optical Cable Corporation
Henson	Toland	OFS Fitel
David	Watson	Southwire Company
Jared	Weitzel	Prysmian Group
Lee	Perry	Service Wire Company
Nigel	Hampton	NEETRAC
Ewell	Robeson	Carolina Power & Light

Section 1

General

1.1 Scope

This Standard applies to materials, constructions, and testing of 2000 volts and less thermoplastic and thermoset insulated wires and cables that are used for the transmission and distribution of electrical energy for normal conditions of installation and service, either indoors, outdoors, aerial, underground, or submarine.