

NEMA Standards Publication WC 73-2000 (R2018)

Wire Selection Guidelines for Wires Rated at 200–450°C

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

www.nema.org

© 2018 National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

NEMA standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

Foreword

This standard has been developed by the WC 73 task force under the Electronics/Communications and Control Cable Subcommittee (members as listed below) of the High Performance Wire and Cable Section of NEMA in close coordination between manufacturers, users, third-party certifying agencies and others having specialized experience. The High Performance Wire and Cable Section of NEMA periodically reviews this standard for any revisions necessary to keep it up to date. Proposed revisions or comments should be submitted to:

Senior Technical Director, Operations
National Electrical Manufacturers Association
1300 North 17th Street, Suite 900
Rosslyn, Virginia 22209

At the time of reaffirmation, the section comprised the following companies:

AFC Cable Systems	New Bedford, MA
Apical Division, Kaneka Texas Corporation	El Dorado, AR
Belden Inc.	St. Louis, MO
Cable USA LLC.	Naples, FL
Champlain Cable Corporation	Colechester, VT
Coleman Cable Inc.	Waukegan, IL
Freeport McMoRan Copper and Gold	Phoenix, AZ
General Cable	Highland Heights, KY
Harbour Industries LLC.	Shelburne, VT
IWG High Performance Conductors	Inman, SC
The Monroe Cable Corporation, Inc.	Middletown, NY
Nexans AmerCable	Houston, TX
The Okonite Company	Ramsey, NJ
Quirk Wire Company, Inc.	West Brookfield, MA
Rubadue Wire Company	Greeley, CO
RSCC Aerospace and Defense	East Granby, CT
Southwire Company	Carrollton, GA
The Monroe Cable Company, Inc.	Middletown, NY
TE Connectivity	Menlo Park, CA
WireMasters, Inc.	Columbia, TN

This standard was developed with the participation of members from The Committee on Mold Safety of the Society of the Plastics Industry, Washington, D.C.

CONTENTS

Foreword i

Section 1 Scope **1**

Section 2 Referenced Standards..... **2**

Section 3 Background **3**

Section 4 Description of Conductors **4**

 4.1 Conductor Composition 4

 4.2 Temperature Range 4

 4.3 Gauge Size 4

Section 5 Ampacities And Correction Factors..... **6**

 5.1 Introduction..... 6

 5.2 Base Ampacities 6

 5.3 Temperature Correction Factors 8

 5.4 Correction Factors For More Than Three Conductors 9

Section 6 Ampacity Calculation Examples From The Hot Runner Industry..... **10**

 6.1 Background 10

 6.2 General Calculation Example..... 11

Section 7 Summary and Conclusions..... **21**

Tables

4-1 Temperature Range..... 4

4-2 Typical Wire Types 5

5-1 Allowable Ampacities of Insulated Conductors Rated 0 Through 2000 V, 60°C to 90°C (140°F to 194°F) Not More Than Three Current-Carrying Conductors in Raceway or Cable or Earth (Directly Buried), Based on Ambient Temperatures of 40°C (104°F)..... 6

5-2 Allowable Ampacities of Insulated Conductors Rated 0 Through 2000 V, 60° to 90°C (140°F to 194°F) Not More Than Three Current-Carrying Conductors in Raceway or Cable or Earth (Directly Buried), Based on Ambient Temperatures of 40°C (104°F)..... 7

5-3 Correction Factors for Ambient Temperatures Other Than 40°C (104°F), Multiply the Ampacities Shown in Tables 5-1 and 5-2 by the Appropriate Factor Shown Below..... 8

5-4 Adjustment Factors for More Than Three Current-Carrying Conductors in a Raceway or Cable (NEC Table 310-15(b)(2)(a))..... 9

6-1 Actual Load Based on Number of Conductors 11

6-2 Wiring Information..... 19

Figures

1 Actual Load Based On Number of Conductors for 12 AWG NCC CLASS 2-10 Rated 250°C..... 12

Section 1

Scope

This standard contains guidelines for calculating amperages and selecting wires for temperatures from 200°C to 450°C and for voltage ratings up to and including 1000 volts rms.

Ampacity charts, temperature correction factors, and derating factors are provided along with extensive examples of calculations.

This information is provided to assist the user in their selection of a wire or cable for a particular application. This guideline contains the best engineering estimates for calculation, but it cannot guarantee a successful performance. It is recommended that a trial installation be prepared and appropriate evaluations be conducted to assure acceptable performance of the completed systems.